Artifact-free, high-temporal-resolution *in vivo* opto-electrophysiology with microLED optoelectrodes

Kanghwan Kim[1], Mihály Vöröslakos[1, 2], John P. Seymour[1], Kensall D. Wise[1], György Buzsáki[2], and Euisik Yoon[1]

[1] Department of Electrical Engineering and Computer Science, University of Michigan, Ann Arbor, Michigan 48109, USA
[2] Neuroscience Institute, Langone Medical Center, New York University, New York, NY 10016, USA

Abstract

The combination of *in vivo* extracellular recording and genetic-engineering-assisted optical stimulation is a powerful tool for the study of neuronal circuits. Precise analysis of complex neural circuits requires high-density integration of multiple cellular-size light sources and recording electrodes. However, high-density integration inevitably introduces stimulation artifact. We present minimal-stimulation-artifact (miniSTAR) μLED optoelectrodes that enable effective elimination of stimulation artifact. A multi-metal-layer structure with a shielding layer effectively suppresses capacitive coupling of stimulation signals. A heavily-boron-doped silicon substrate silences the photovoltaic effect induced from LED illumination. With transient stimulation pulse shaping, we reduced stimulation artifact on miniSTAR μLED optoelectrodes to below 50 μV_{pp}, much smaller than a typical spike detection threshold, at optical stimulation of > 50 mW mm^{-2} irradiance. We demonstrated high-temporal resolution (< 1 ms) opto-electrophysiology without any artifact-induced signal quality degradation during *in vivo* experiments. MiniSTAR μLED optoelectrodes will facilitate functional mapping of local circuits and discoveries in the brain.

Introduction

A brain is made up of densely populated neurons. Analysis of neuronal communication requires simultaneous high-resolution recording and neuron-specific perturbation of circuit components under controlled conditions. The combination of genetic engineering-assisted optical stimulation and massively parallel electrical recording of neuronal activities (opto-electrophysiology) is a promising tool for studying neuronal circuits in behaving animals[1]. A number of devices[2-11] have been introduced for the past few years for *in vivo* opto-electrophysiology. For high-resolution *in vivo* opto-electrophysiology, a micromachined silicon multi-electrode-array structure also known as the Michigan Probe[12,13] has been widely utilized[6-11]. These silicon optoelectrodes take advantage of the planar profile of the Michigan Probe platform and accommodate multiple light sources in the vicinity of high-density recording electrode arrays. This compact configuration provides the capability to electrically record activity of sets of neurons at high spatial resolution while optically stimulating a portion of the recorded neurons.

An undesirable feature of many of these devices is stimulation artifact. With its magnitude often an order of magnitude larger than those of underlying neuronal signals, the stimulation artifact may mask neuronal signals and prevent temporally precise recording of neuronal responses[14,15]. In order to enable precise detection of neuronal activities, the magnitude of the stimulation artifact should be reduced to lower than a threshold voltage level for neuronal activity detection. Typically, the threshold level is set as a few integer multiples (often 5 ×) of the root-mean-square value of background noise[16,17]. To keep the artifact magnitude lower than the threshold level, optical stimulation had been limited to slowly-changing, low-frequency pulses, such as slow (< 10 Hz) sine waves[11] or trapezoidal pulses with a long (> 10 ms) rise time[18]. These slowly-changing optical stimulation protocols, however, are not suitable for many neuroscience experiments in which high-speed neuromodulation is required, such as those in closed-loop experimental setups[19]. An ideal optoelectrode should therefore provide optical

stimulation with temporal resolution higher than the duration of the neuronal activities while keeping the stimulation artifact magnitude lower than a spike detection threshold.

We present minimal-stimulation-artifact (miniSTAR) µLED optoelectrode and report the engineering schemes that enabled artifact-free optical stimulation. We extensively characterized various forms of optical-stimulation-induced artifacts, including photoelectrochemical effects (PEC)[20-25], electromagnetic interference (EMI)[6,26,27], and photovoltaic effects (PV)[28,29]. MiniSTAR optoelectrodes utilize monolithically integrated neuron-sized LEDs[11] for high spatial resolution optical stimulation of target neurons. The multi-metal-layer structure on the miniSTAR optoelectrode suppresses EMI-induced stimulation artifact, and the heavily-boron-doped silicon substrate eliminates PV-induced artifact. Additionally, transient pulse shaping control reduces the magnitude of residual stimulation artifact on all recording channels to < 50 µV peak-to-peak (µVpp) without compromising the temporal resolution of optical stimulation. With an *in vivo* experiment using a miniSTAR optoelectrode implanted in a mouse brain, we demonstrate the absence of distortion in the recorded neuronal signals during precise *in situ* optical stimulation.

Results

Fabrication and characterization of miniSTAR µLED optoelectrodes

We fabricated miniSTAR µLED optoelectrodes (Fig. 1a) using microfabrication techniques adapted from those used for the fabrication of the family of Michigan optoelectrodes including one-metal-layer µLED optoelectrodes[11]. Figure 1b describes the simplified device fabrication flow. MiniSTAR optoelectrodes were fabricated using gallium-nitride-on-silicon (GaN-on-Si), gallium nitride/indium gallium nitride multi-quantum-well (GaN/InGaN MQW) LED wafers with heavily boron-doped silicon (p^+-Si, $N_A \approx 1 \times 10^{20}$ cm^{-3}) substrates. In order to reduce EMI-induced stimulation artifact, metal traces for LED drive signals (LED interconnects) and those for recorded neuronal signals (recording electrode

interconnects) were placed in two different metal layers separated from each other by a ground-connected shielding layer (Fig. 1c, top), forming a multi-metal-layer structure. A heavily-boron-doped substrate was chosen to suppress diffusion of optically generated electron-hole pairs and, as a result, to reduce PV-induced stimulation artifact (Fig. 1c, bottom). First, LED mesa structures were formed on GaN/InGaN MQW layer, and the LED interconnects were defined on the first metal layer. After passivating the surface of the LEDs, the EMI shielding layer was defined on the second metal layer and the recording electrode interconnects were defined on the third metal layer. Neural signal recording electrodes were then formed by depositing electrode material (iridium) on top. Finally, the entire wafer was thinned down to 30 μm and the miniSTAR optoelectrodes were released from the silicon wafer. Released miniSTAR optoelectrodes were assembled on printed circuit boards (PCBs) that provide connections to a neuronal signal recording IC and an LED driver (Fig. 1d). Figure 1e shows a microphotograph of a tip of the fabricated miniSTAR optoelectrode. The dimensions of exposed surface area of each μLED and recording electrodes are 10 × 15 μm and 11 × 13 μm (W × L), respectively.

After fabricating the miniSTAR optoelectrodes, we characterized performance of the LEDs and recording electrodes and confirmed that they are suitable for *in vivo* opto-electrophysiology. Optical power equivalent to greater than 1 mW mm^{-2} of irradiance is considered a threshold for activation of channelrhodopsin-2 (ChR2)[9,11]. LEDs on miniSTAR optoelectrodes generated a radiant flux of 150 nW, equivalent to an irradiance of 1 mW mm^{-2} at the surface when voltage of 2.86 ± 0.02 V (mean ± SD, n = 22) was applied across their terminals. The LEDs were capable of generating 50 mW mm^{-2} at the surface (7.5-μW radiant flux) at 3.46 ± 0.10 V, which is more than sufficient for activation of ChR2-expressing cells further away from the LED surface. We confirmed that the effect of substrate doping density on the electrical and optical characteristics of the fabricated LEDs is not as significant as the die-to-die variation in a wafer (Supplementary Figure 1). The impedance magnitude and phase of the recording electrodes

were measured as 1.15 ± 0.07 MΩ and -68.33 ± 5.11 ° at 1 kHz (n = 54, mean ± SD), respectively, acceptable for high-quality *in vivo* extracellular recordings[30].

Reduction of EMI-induced artifact

EMI is inevitable in a system where a source of high-voltage, fast-changing signal is located in close proximity to a signal-carrying trace connected to a high-impedance load. Previous μLED optoelectrodes[30] contained only one metal layer on which all the interconnects that carry optical stimulation signals as well as those carrying recorded neural signals were densely integrated. Therefore, mutual capacitances between the traces of two signal types were high, and, in turn, the recording interconnects were highly susceptible to EMI from LED drive signals. Moreover, the n-GaN layer that forms the common cathode of all the μLEDs on the optoelectrode was directly underneath the interconnects and acted as another significant source of EMI. FEM simulations of electrostatic potential distribution in the one-metal-layer μLED optoelectrode (Supplementary Results and Supplementary Figure 2c) showed significant voltage coupling from LED interconnects (-48.96 dB) as well as from the n-GaN layer (-0.06 dB).

We observed significant suppression of EMI-induced stimulation artifact with the integration of a shielding layer. We implemented the triple-metal-layer structure on μLED optoelectrode and dedicated a layer between the stimulation and recording interconnects as a shielding layer (Supplementary Figure 2d). Triple-metal-layer (shielded) μLED optoelectrodes were fabricated on the same GaN-on-Si LED wafer on which one-metal-layer μLED optoelectrodes were fabricated, which had a lightly boron-doped silicon substrate ($N_A \approx 5 \times 10^{16}$ cm^{-3}). We compared stimulation artifacts between one-metal-layer μLED optoelectrodes and shielded μLED optoelectrodes while turning on and off μLEDs *in vitro*.

Figure 2 shows the magnitude of the transient artifact (peak-to-peak) and the wideband and highpass filtered waveforms of artifacts resulting from optical stimulation. One-metal-layer μLED optoelectrodes showed a high transient magnitude (> 1 mVpp) in most recording sites regardless of the amount of optical power generated from the LEDs (Fig. 2b). The shape of wideband stimulation artifacts (Fig. 2c, left) suggests strong EMI-induced artifact. The weak dependence of stimulation artifact on optical power suggests that voltage coupling from the n-GaN substrate, whose voltage does not greatly change as a function of the LED signal voltage, greatly contributes to the EMI-induced stimulation artifact. On the other hand, shielded optoelectrodes showed significantly lower artifact (100 - 400 μVpp) which gradually increases at larger irradiance (Fig. 2e). It was also verified from both the wideband (Fig. 2f, left) and the highpass filtered waveforms (Fig. 2f, right) that the EMI-induced artifact has been greatly reduced. This result was consistent with expectation from the FEM simulations (Supplementary Figure 2c). Significant reduction of stimulation artifact on shielded optoelectrodes was observed at all irradiance under test (Fig. 2g). At 75-mW mm^{-2} irradiance (radiant flux of 11.5 μW), we achieved 5.2-fold reduction in stimulation artifact (from 2477.75 ± 1733.83 to 474.59 ± 146.26 μVpp, n = 75 and 67, respectively).

Elimination of PV-induced artifact

Although EMI-induced artifact was greatly suppressed with introduction of the shielding layer, the magnitude of the residual artifact was still high and should be further eliminated below that of typical neuronal spikes (~ 100 μVpp). Interestingly, we noticed that the polarity of stimulation artifact at the rising and falling edges of LED drive pulses were inverted on the shielded μLED optoelectrodes. As can be seen in Fig. 2c, the transient artifact on one-metal-layer μLED optoelectrodes has the same positive polarity as that of the LED drive signal, forming an inverted-'v' (or '^') shaped waveform. However, on the shileded μLED optoelectrodes (Fig. 2f and h), the polarity of the transient artifact was

inverted, making a v-shaped waveform. Inversion of the polarity of the transient artifact suggested that

the residual artifact could result from a different source other than EMI.

We hypothesized that the source of v-shaped stimulation artifacts is photovoltaic (PV) effects in

the silicon substrate and confirmed our hypothesis with a few experiments. First, we observed the

waveform of signals recorded on electrodes while exposing the μLED optoelectrodes to external optical

illumination. Using a focused beam at a wavelength similar to that of the light generated from μLEDs

($\lambda_{peak} \cong 470$ nm), we illuminated tips of the shielded μLED optoelectrodes. The shape of induced voltage

signals was identical to that of the stimulation artifact observed on the optoelectrodes (Supplementary

Figure 3). The identical shape suggested that the artifact is truly optically induced, not resulting from

EMI. We repeated the experiment using electrode arrays fabricated on non-silicon substrates: GaN-on-

sapphire wafer and soda lime glass. We did not observed any v-shaped stimulation artifacts on

electrodes on both substrates (Supplementary Figure 4), verifying that the artifact is due to neither

photoelectrochemical (PEC) effects on the electrodes nor PV-induced artifact on the GaN layer. With the

exclusion of PEC effects and PV effect from the GaN layer, the only remaining source of potential light-

induced artifact is the PV effects from the silicon substrate.

A few experimental studies in the past reported that light-induced noise on silicon electrode

arrays can be reduced with use of heavily-doped substrate[31,32]. Heavy doping of semiconductor greatly

reduces carrier lifetimes[33,34] and diffusion lengths of free carriers, which supposedly contributes to the

amount of dipole-induced voltage[31]. Therefore, PV-induced stimulation artifacts should be suppressed

with heavy doping of the silicon substrate. We conducted FEM simulations of optically induced voltage

generation in silicon substrates and verified that the voltage is reduced with heavy substrate doping. We

built a model of the silicon substrate and calculated the optically-induced voltage generation while

changing doping concentrations (Supplementary Methods). The results suggest that highly a boron-

doped silicon substrate can greatly reduce the magnitude of optically induced voltage and as a result suppress PV-induced artifact (Supplementary Results and Supplementary Figure 5).

In order to verify the effect of doping density on the magnitude of PV-induced stimulation artifact, we fabricated three groups of shielded μLED optoelectrodes using GaN-on-Si GaN/InGaN MQW LED wafers with different silicon substrates: float-zone grown silicon substrate (FZ-Si, $N_A \approx 4 \times 10^{12}$ cm^{-3}), lightly boron-doped silicon substrate (p$^-$-Si, $N_A \approx 5 \times 10^{16}$ cm^{-3}), and heavily boron-doped silicon substrate (p$^+$-Si, $N_A \approx 1 \times 10^{20}$ cm^{-3}). Fig. 3a shows that the magnitude of stimulation artifact measured on the optoelectrodes fabricated using wafers with FZ-Si and p$^-$-Si substrates increases as a function of irradiance (FZ-Si: 109.59 ± 80.61 μVpp at 1.5 mW mm^{-2} increasing to 569.33 ± 129.00 μVpp at 75 mW mm^{-2}, p$^-$-Si: 99.25 ± 116.01 μVpp at 1.5 mW mm^{-2} increasing to 474.59 ± 146.26 μVpp to at 75 mW mm^{-2}, mean ± SD). On the other hand, the stimulation artifact magnitude on devices with p$^+$-Si substrate did not show significant change (133.04 ± 121.99 μVpp at 1.5 mW mm^{-2} to 146.05 ± 143.4 μVpp at 75 mW mm^{-2}, mean ± SD). The magnitude of stimulation artifact as a function of irradiance and substrate doping density (Fig. 3b) was similar to that expected from FEM simulation (Supplementary Figure 5d). Figure 3c shows the waveforms of stimulation artifact measured on the optoelectrodes of each group. It can be seen that even with high-intensity illumination (11.5 μW, 75 mW mm^{-2}), the mean magnitude of stimulation artifact was below 200 μVpp, suggesting that PV-induced stimulation artifact was effectively reduced by use of heavily-boron-doped silicon substrate.

We confirmed elimination of the PV-induced stimulation artifact by inspecting the shape and the magnitude of stimulation artifact waveforms recorded from electrodes at different locations on μLED optoelectrodes (Fig. 4). Figure 4b shows the magnitude of stimulation artifact recorded from channels that correspond to the electrodes marked in Fig. 4a. The artifact waveform recorded from each channel is presented in Fig. 4c. It is interesting to note that, while the v-shaped waveform in stimulation artifact was observed in the recordings from optoelectrodes with FZ-Si and p$^-$-Si substrates, we no

longer observed the v-shape in the optoelectrodes with p$^+$-Si substrates. The absence of the characteristic v-shaped waveform confirms that PV-induced stimulation artifact has been eliminated on the optoelectrodes with p$^+$ silicon substrate.

Suppression of residual EMI-induced artifact by transient stimulation pulse shaping

Considering great reduction of both EMI- and PV-induced stimulation artifact, we refer to the shielded μLED optoelectrodes fabricated using LED wafer with p$^+$ silicon substrate as minimal-stimulation-artifact (miniSTAR) μLED optoelectrodes. We quantified the amount of reduction in stimulation artifact from the implementation of shielding layers and the replacement of substrate with highly-boron doped silicon in miniSTAR optoelectrodes (Supplementary Figure 6). The magnitude of artifact was reduced by a factor of 5.2 in average only from the shielding layers (from 2477.75 ± 1733.83 to 474.59 ± 146.26 μVpp, at 11.5 μW, mean ± SD), and by a factor of 17 in average from both shielding and substrate replacement combined (to 146.05 ± 143.40 μVpp, at 11.5 μW, mean ± SD). However, the magnitude of stimulation artifact in a couple of recording sites (sites 1 and 2) was still high, as large as 200 - 300 μVpp, while those on some other sites (sites 7 and 8) were less than 50 μVpp (Fig 4e).

Location dependence of residual stimulation artifact revealed that the residual artifact is due to EMI resulting from imperfection in the shielding layer. The shieling layer on miniSTAR optoelectrode contains openings (or optical windows) on top of μLEDs for illumination. However, the optical windows allow the electric field generated from the LEDs to exit the shielding layer and makes the interconnects susceptible to EMI. Once the PV-induced artifact was removed in miniSTAR optoelectrodes, we observed emergence of ^-shaped waveforms (Fig. 4c), which is especially pronounced on sites 1 and 2. The magnitude of ^-shaped waveform is inversely proportional to the distance between the interconnect for each site and the optical window on the shielding layer (Fig. 4c-e). The polarity and the distance

dependence of stimulation artifact waveforms suggest that this residual artifact is due to EMI originating from the LEDs that are exposed through optical windows on the shielding layer.

Additional suppression of residual artifact was achieved by transient pulse shaping of LED drive signal. We modified the slew rate of voltage pulses by changing the rise and fall times of the pulses. With sufficiently long rise time ($t_{rise} > (2\pi F_s)^{-1}$), the magnitude of higher-order harmonics of the coupled signal that contributes to the artifact ($(\pi t_{rise})^{-1} < f < F_s/2$) is reduced by additional -20 dB/decade (Supplementary Figure 7). Figure 5 shows the peak-to-peak magnitude and waveforms of stimulation artifact recorded from the channels corresponding to the bottom two electrodes (sites 1 and 2) on the tip of miniSTAR optoelectrodes, which show the worst residual EMI-induced artifact. We observed significant reduction in stimulation artifact as we increased the rise time longer than 100 μs. At 50 mW mm^{-2} irradiance, the artifact magnitude was reduced below 200 μVpp (173.99 ± 55.76 μVpp, mean ± SD, for 1-ms rise time). In order to further reduce the slew rate of the voltage driving signal, we adjusted the low-level (or off-state) voltage in the stimulation pulse signals. We increased the low-level voltage to 2.8V, just below the lowest turn-on voltage of LEDs. The voltage required for irradiance of 50 mW mm^{-2} (radiant flux of 7.5 μW) is approximately 3.5 V. By adjusting the low-level voltage from 0 V to 2.8 V, we reduced the voltage swing from 3.5 V to 0.7 V and the slew rate by a factor of 5. We confirmed that the artifact magnitude can be reduced to 111.92 μVpp (SD = 55.76 μVpp) even without adjusting the rise time (Fig. 5b, V_{low} = 2.8 V, blue). With a 1-ms rise time and 2.8-V low-level voltage, the mean artifact magnitude was reduced to 46.53 μVpp (SD = 11.33 μVpp). In typical *in vivo* extracellular measurements, 100 μVpp is used as a spike detection threshold due to biological and environmental noise. Therefore, stimulation artifact with less than 50-μVpp magnitude can be considered nearly artifact-free.

Validation of stimulation-artifact-free *in vivo* opto-electrophysiology

Following *in vitro* characterization, we demonstrated successful elimination of supra-threshold

stimulation artifact *in vivo*. We implanted a miniSTAR μLED optoelectrode in the brain of a mouse and

positioned its tips in the CA1 region of the hippocampus (Fig. 6a). Once spontaneous spikes and the

characteristic high-frequency oscillations (ripples) were detected from the recording electrodes on a

shank, each LED on the shank was turned on with varying powers to identify the optimal intensity of

optical stimulation to alter the spiking activity of neurons ('localized effect') without inducing high-

frequency oscillations due to synchronized firing of neuron populations[11]. Considering the typical

duration of an action potential (< 2 ms), we used a rise/fall time of 1 ms to ensure maximum reduction

of stimulation artifact without loss of the temporal resolution in optical stimulation.

Stimulation with a 460-nW radiant flux (irradiance of 3 mW mm^{-2} at the surface of each μLED)

induced strong light-induced responses in adjacent neurons. Optical stimulation with higher intensities

induced high-magnitude (> 100 μVpp) population bursting of multiple cells[11], preventing identification of

single neurons and analysis of stimulation artifact. The mean waveform of signal the recorded from

channels corresponding to electrodes at different locations on the shank (Fig. 6b) during the onset of

the 3-mW mm^{-2} optical stimulation is shown in Fig. 6c. No supra-threshold (> 50 μVpp) stimulation

artifact was observed from most channels.

After characterization of the stimulation artifact while driving individual LEDs, all three LEDs on

the same shank were turned on and off in an interleaved manner (highlighted with a rectangle with

black dashed lines in Fig. 6d). As shown in Fig. 6d, the series of optical pulses did not generate noticeable

stimulation artifacts that would prevent either online detection of spikes or their offline spike sorting.

With offline spike sorting[35], we identified 6 putative pyramidal neurons with distinct spike waveforms in

the vicinity of the shank on which the LEDs were activated. Further analysis of processed data identified

a neuron which was clearly detected at the time stimulation offset of LED 1 and onset of LED 3 (Fig. 6f).

No noticeable distortion of the spike waveform was present due to optical stimulation (Fig. 6g).

Discussion

Results of this study the demonstrated the capability of high-spatiotemporal-resolution *in vivo* opto-electrophysiology with miniSTAR µLED optoelectrodes. We validated that the implementation multi-metal-layer structure, high-density boron doping of silicon substrate, and transient pulse shaping of stimulation waveform can effectively suppress stimulation artifact. A few non-ideal features in the fabricated miniSTAR optoelectrodes prevented the magnitude of the stimulation artifact from being further reduced. One imperfection is existence of optical windows on the shielding layer, which allow EMI generated from LEDs to reach their neighboring recording electrode interconnects. The other non-ideal factor is that the shielding layer has non-zero resistance. The shielding layer, especially near the tips of the shanks, is not strictly an ideal ground due to a resistive voltage drop through the thin-film metal layer it is made of. This resistive voltage drop would make the voltage of the shielding layer fluctuate as the voltage of LED interconnect changes, and the shielding layer itself could have acted as a source of EMI. These non-ideality resulted in less efficient reduction of EMI-induced artifact than that FEM electrostatic simulation predicted.

Residual EMI artifact might be able to be further suppressed with a few additional techniques. First, techniques to reduce the mutual capacitance between the recording electrode interconnect and the LED anode interconnect can be utilized. Increasing the distance between the recording electrode interconnects and the optical windows on the shielding layer (Fig. 4d) results in reduction of the mutual capacitance. Alternatively, a pair of ground-connected traces serving as shielding guards could have been placed between the optical windows and the recording electrode interconnects. However, these measures to reduce the mutual capacitance would inevitably increase the width of the shanks. Shank width is the main limiting factor for high-density scaling of the device which is required for larger-scale recording applications. Therefore, these options might not be considered optimal.

Methods to reduce electrode impedance might also be utilized for further reduction of EMI-induced artifact. The current carrying the capacitively coupled signal is divided between two branches in the signal recording circuit each of which is terminated with the amplifier load and the electrode (Supplementary Figure 8a). Therefore, lowering the electrode impedance would result in less current flowing through the amplifier load and thus reduction in the magnitude of the recorded voltage. In the data we collected using fabricated miniSTAR optoelectrodes, however, no obvious correlation between the electrode impedance and the magnitude of the stimulation artifact was observed (Supplementary Figure 8b). The small variance in the electrode impedance magnitude could have contributed to the lack of correlation. In future versions of miniSTAR optoelectrodes, electrode surface modification techniques such as site-level electrodeposition of conductive nanoparticles (e.g. Pt nanoparticle[36,37] and PEDOT:PSS[38-40]) might be utilized to reduce the electrode impedance. The relationship between the electrode impedance and the stimulation artifact magnitude can then be studied in depth with groups of different miniSTAR optoelectrodes with significantly different electrode impedance ranges.

Transient stimulation pulse shaping complements the two engineering schemes of structural changes implemented in the miniSTAR optoelectrodes and effectively eliminates stimulation artifact. With nearly-zero amplitude artifact, miniSTAR optoelectrodes can be readily utilized for applications that require real-time event detection and closed-loop perturbation of neural circuits[1,19]. Still, the tradeoff between the temporal precision of optical stimuli and the amount of reduction in stimulation artifact should be taken into consideration. Most opsins have slow kinetics and will not provide sub-millisecond-precision responses regardless of the precision of optical stimulus. Short-pulse optical stimulation protocols, similar to electrical protocols utilizing a train of sub-millisecond pulses[41], might be found useful in combination with some fast-responding opsins[42,43]. Generation of such short (< 2 ms) optical pulses may result in discernable signatures (> 50 μVpp) in the recordings. These potential supra-threshold-amplitude artifacts, however, can easily be subtracted[44] from the recorded trace since they

occur at predetermined times and display identical waveforms. Therefore, residual stimulation artifact would not significantly compromise the quality of recording.

In some applications, current-based LED driving might be more desirable than voltage-based driving. When driven with current pulses, the voltage changes across the two terminals of an LED would follow the I-V characteristics of the LEDs. Therefore, current driving allows setting the non-zero off-state voltage across an LED, typically just below the LED turn-on voltage (≈ 2.8 V). We validated that the effect of current-based driving of LEDs is similar to that with voltage-based driving of LEDs with non-zero low-level voltage (Supplementary Figure 9). We further tested pulses with three different rise- and fall-time shapes: trapezoidal, sinusoidal and sigmoidal. The shape of current pulses during on- to off-state transition did not significantly affect the magnitude of stimulation artifact. This result suggests that, if stimulation pulses have sufficiently low slew rate, smoothening of pulse edges does not necessary provide additional reduction in stimulation artifact magnitude.

Overall, our work demonstrates that stimulation artifact can be successfully suppressed using miniSTAR μLED optoelectrodes. This new device will allow performing high temporal resolution *in vivo* opto-electrophysiology for in-depth understanding of the interactions among the multiple components of neuronal circuits.

Methods

Shielded μLED optoelectrode fabrication and device assembly

Four-inch-diameter silicon wafers with different substrate boron doping densities ($N_A \approx 4 \times 10^{12}$, 5×10^{16}, and 1×10^{20} cm^{-3}, respectively) with GaN/InGaN multi-quantum-well (MQW) LED layers epitaxially grown with metal-organic chemical vapor deposition (MOCVD) on top were purchased from Enkris Semiconductor (Suzhou, China). LED structures, including LED mesas, p- and n-GaN contacts and metallic interconnects, were first formed on the wafer. Repeated deposition of passivating dielectric

layers and deposition of patterned metal layers formed additional metal layers. Consecutively, the top

metal layer was passivated, and neural signal recording electrodes were defined. Finally, fabricated

μLED optoelectrodes were thinned and released from the silicon wafer by double-sided plasma dicing

process. The detailed fabrication process, including the list of tools used for each fabrication step, is

provided in Supplementary Methods.

In order to prevent unwanted capacitive voltage coupling at assembly level, we used four-layer

printed circuit boards (PCBs) on which the traces for recorded neuronal signals and LED drive signals are

separated by two ground-connected internal layers. The optoelectrodes were mounted on the PCBs and

were electrically connected to the PCBs by wirebonding contact pads on the backend of the

optoelectrode to the gold pads on the PCBs. After wirebonding, exposed wires were potted with epoxy

(EPO-TEK 353ND and 353NDT, Epoxy Technology, Billerica, MA), and connectors (Omnetics Connector

Corp., Minneapolis, MN) as well as the ground and the reference wires were soldered to the PCBs to

finalize assembly process.

Characterization of the electrical and optical properties of the μLEDs

The electrical and optical properties of each μLED on the μLED optoelectrodes were

characterized before *in vitro* and *in vivo* characterization of stimulation artifact. Both current-voltage (I

vs.V) and the irradiance-voltage (E_e vs. V) characteristics were measured for each μLED. First, an optical

measurement system consisting of an integrating sphere (FOIS-1, Ocean Optics, Largo, FL) and a

spectrometer (Flame, Ocean Optics) was built. A sourcemeter (Keitheley 2400, Keithley Instruments,

Cleveland, OH) was then connected across the anode and the cathode pins of an μLED on the connector.

The tips of the optoelectrode were lowered until the whole shanks were completely inside the

integrating sphere, ensuring that all the light generated from the μLED can be collected. The DC voltage

across the LED anode and the cathode terminals were swept from 0 V to 4 V, and the resulting current

and the spectral flux of the µLED were measured. The radiant flux was calculated by integrating the

spectral flux over wavelengths from 350 nm to 600 nm, and the irradiance on the surface of the µLED

was then calculated by dividing the radiant flux by the µLED's surface area (150 µm²).

Characterization of the electrical properties of the recording electrodes

The impedance (both the magnitude and the phase at 1 kHz) of each recording electrode on the

µLED optoelectrode was measured using an Intan neural signal recording amplifier (RHD2132, Intan

Technologies, Los Angeles, CA) in 1 × phosphate buffered saline (PBS) solution (prepared using 10 × PSB

purchased from MP Biomedicals, Solon, OH). First, a small amount of PBS (approximately 100 mL of 1 ×

PBS solution) was poured into a small clear polystyrene container (530C-CRY, AMAC Plastic Products,

Petaluma, CA). The µLED optoelectrode was lowered into the container until the bottom halves of the

shanks (~ 2.5 mm) were submerged in PBS. Exposed stainless steel tips at the loose ends of the ground

and the reference wires were also submerged in PBS. A neuronal signal recording system (RHD2000,

Intan Technologies) conducted electrode impedance measurements.

Setup for *in vitro* characterization of LED-drive-induced artifacts

In vitro characterization was conducted in 1 × PBS solution in AMAC 530C-CRY container. An

µLED optoelectrode was lowered into the container until the bottom halves of the shanks were

submerged in PBS. The exposed stainless steel tips at the loose ends of the ground and the reference

wires were also submerged in the PBS.

An Intan RHD2000 neuronal signal recording system, in combination with an Intan RHD2132

miniature neural signal amplifier headstage PCB, recorded stimulation artifacts at a 20-kHz sampling

rate, while a function generator (33220A, Keysight Technologies, Santa Rosa, CA) provided voltage

pulses for LED driving. 50-ms long (5 Hz frequency, resulting in 25 % duty ratio) rectangular voltage

pulses were used as LED drive signals. The off-time (low-level) voltage, on-time (high-level) voltage, pulse rise time, and pulse fall time were varied for different experiments. The experimental conditions used for each type of experiment are summarized in Supplementary Table 1. Before the LED drive signal was provided, the impedance (both the magnitude and the phase at 1 kHz) of each recording electrode on the μLED optoelectrode was measured using the Intan amplifier.

Characterization of the effect of the shielding layer on the magnitude of *in vitro* LED-drive-induced artifact

Two one-metal-layer μLED optoelectrodes and two shielded μLED optoelectrodes, all of which were fabricated using the LED wafer with p$^-$ silicon substrate (boron doped, $N_A \approx 5 \times 10^{16}$ cm^{-3}), were used. First, the high-level voltages required for generation of radiant flux of 230 nW - 11.5 μW (LED surface irradiance of 1.5 - 75 mW mm^{-2}) were calculated. The high-level voltage of the LED drive pulse signal was varied according to the target irradiance, while the low-level voltage was fixed at 0 V and the rise time (as well as the fall time) was fixed as 5 ns (10 – 90 %, equivalent to 6.25 ns of 0 – 100 % rise and fall times).

Characterization of the effect of the boron doping of the silicon substrate on the magnitude of *in vitro* LED-drive-induced artifact

Six shielded μLED optoelectrodes fabricated using LED wafers with FZ, p$^-$, and p$^+$ silicon substrate (two optoelectrodes from each wafer) were used. LED drive signals identical to those used for characterization of the effect of the shielding layer were used.

Characterization of the effect of the transient stimulation pulse shaping on the magnitude of i*n vitro* LED-drive-induced artifact

Two miniSTAR μLED optoelectrodes (shielded μLED optoelectrodes fabricated using LED wafers p⁺ silicon substrate) were used. The low-level voltage and the rise time of the LED drive pulse signal were varied, while the high-level voltage was fixed as 3.5 V. Low-level voltages of 0 V and 2.8 V were used, and rise and fall times (10 – 90 %) between 5 ns and 1 ms were used.

Recording of *in vitro* LED-drive-induced artifact and data processing

For each experimental condition for each μLED, signals from the input channels of the neural signal amplifier IC were recorded for 30 seconds, so that artifact signals from longer than 100 pulses can be recorded. Average artifact signal was calculated by first highpass filtering the signal to remove low-noise fluctuations (with filters with 10 Hz and 250 Hz cutoff frequencies for wideband signal and highpass filtered signals, respectively) and calculating the average of the fifty 200-ms long segments in the middle of the 30 second period after the first 5 s of the recorded signal. Transient artifact magnitude was calculated from the difference between the maximum and the minimum values of high-pass filtered signal during the first 5-ms period from the point when the voltage changed from the off-level voltage. The mean transient artifact magnitude was calculated by taking the mean of the values from electrode whose impedance magnitudes are between 500 kΩ and 2 MΩ and the phases are between -80 ° and -55 ° at 1 kHz. Two μLED optoelectrodes from each cohort were used, and at least 21 electrodes per optoelectrode (out of 32 total, 25.83 in average) contributed to calculation of the mean artifact magnitude. The mean 1 kHz magnitude and phase of the electrode impedance of the electrodes which contributed to calculation of the mean artifact magnitude were 1.09 ± 0.09 MΩ and -68.2 ± 4.9 ° (mean ± SD, measured at 1 kHz).

***In vivo* characterization and demonstrations of stimulation-artifact-free opto-electrophysiology**

The animal procedures were approved by the Institutional Animal Care and Use Committee of the University of Michigan (protocol number PRO-7275). One male C57BL/6J mouse (32 g) was used for *in vivo* characterization. The mouse was kept on a regular 12 h - 12 h light - dark cycle and housed in pairs before surgery. No prior experimentation had been performed on this animal. Atropine (0.05 mg/kg, s.c.) was administered after isoflurane anesthesia induction to reduce saliva production. The body temperature was monitored and kept constant at 36 - 37 °C with a DC temperature controller (TCAT-LV; Physitemp, Clifton, NJ, USA). Stages of anesthesia were maintained by confirming the lack of nociceptive reflex. Skin of the head was shaved and the surface of the skull was cleaned by hydrogen peroxide (2 %). A 1-mm diameter craniotomy was drilled at 1.5 mm posterior from bregma and 2 mm lateral of the midline. The dura was removed over the dorsal CA1 region of the hippocampus and the mouse was injected with AAV5, CaMKII promoter driven ChR2 (AAV5-CaMKIIa-hChR2(H134R)-EYFP), resulting in expression of ChR2 in pyramidal neurons. Viruses were purchased from the University of North Carolina Vector Core (UNC-REF). After the surgery, the craniotomy was sealed with Kwik-Sil (World Precision Instruments, Sarasota, FL) until the day of recording.

On the day of recording, the mouse was anesthetized with isoflurane, the craniotomy was cleaned, and a shielded µLED optoelectrode with p$^+$ silicon substrate was lowered to the CA1 region of the hippocampus. Baseline recording was performed (30 min), after which simultaneous recording and stimulation were done using three µLEDs from one shank (as described in Results in more details). 0.46 µW power, equivalent to 3 mW mm^{-2} irradiance at the surface of each µLED, was used to characterize the light induced artifact *in vivo* and to alter the activity of neurons (more details are provided in Results). For characterization of stimulation artifact and confirmation of optical induction of neuronal activities, pulsed optical stimulation (100-ms long, 2 Hz, 100 pulses) was generated from each µLED. The (10 - 90 %) rise and the fall times of each voltage pulse were set as 1 ms. After collecting sufficient data using optical stimulation from each µLED, a 500-ms long optical stimulation sequence involving

switching on and off all the three μLEDs on the shank (whose details are provided in Results) were

repeated 100 times. RHD2000 recording system with RHD2132 miniature neural signal amplifier

headstage was used for acquisition of data from all the recording electrodes (n = 32, 20 kS/s sampling

rate). Keysight 33220A function generator provided voltage pulses for LED driving.

A custom MATLAB (MathWorks, USA) script was used to calculate average stimulation artifact.

Wideband traces were first high-pass filtered with a first-order filter with 250 Hz cutoff frequency to

remove low-noise fluctuations. The average artifact signal from each recording channel was then

obtained by averaging the middle 500-ms long segments (90 total segments out of 100).

The recorded data were then further analyzed for identification and clustering of action

potentials. No manipulation in data (e.g. trimming of 1-ms long segments before and after the beginning

and the ending of each pulsed optical stimulation) other than high-pass filtering (at 500 Hz) of the

baseband signal was conducted. Spikes were first detected and automatically sorted using the Kilosort

algorithm[35] and then manually curated using Phy to get well-isolated single units (multi-unit and noise

clusters were discarded). To measure the effect of LED stimulation on neuronal activity, peristimulus

time histograms (PSTHs) were built around stimulus onset (spike trains were binned into 10-ms bins).

Baseline and light-induced firing rate were calculated for each single unit, in which the baseline was

defined as light-free epochs (400 ms) between trials and the stimulation period as the light-on (100 ms).

Wilcoxon-signed rank test was used to compare the mean firing rate per trial (n = 100 trials) during

baseline and LED stimulation.

Figure 1: MiniSTAR optoelectrode. (**a**) Schematic illustration of a miniSTAR μLED optoelectrode. (**b**) Simplified miniSTAR optoelectrode fabrication process. An illustrative cross-section containing only one LED and one recording electrode is shown. (**c**) Cross-sectional schematic diagrams of a shank of miniSTAR optoelectrode, showing sources of stimulation artifact (EMI and PV effect for top and bottom, respectively) and methods for reduction of stimulation artifact. (**d**) Photograph of a miniSTAR optoelectrode mounted on a PCB. **(e)** Microphotograph of a tip of a miniSTAR optoelectrode, on which eight recording electrodes, three LEDs, LED interconnects, shielding layer, and recording electrode interconnects are shown.

Figure 2: Reduced EMI-induced artifact. (**a**) Schematic illustration of the tip of one-metal-layer (non-shielded) μLED optoelectrode. Blue rectangles indicate LEDs, white rectangles the recording electrodes, and yellow polygons interconnects. (**b**) Peak-to-peak magnitude of highpass filtered stimulation artifact recorded on non-shielded μLED optoelectrodes. Data from channels corresponding to all electrodes on the shank on which a LED was turned on are plotted. Boxes indicate interquartile ranges, white lines medians, whiskers non-outlier extreme values, and black x marks outliers. (**c**) Mean waveforms of stimulation artifact recorded on non-shielded μLED optoelectrodes, from channels that correspond to

electrodes on different locations on the tips. LED drive signal with resulting LED surface irradiance of 75

mW mm^{-2} was used. (**d**) Schematic illustration of the tip of shielded μLED optoelectrodes. The color

scheme is identical to that of part **a**, except for an additional color, gold, to indicate shielding layer. (**e**)

Peak-to-peak magnitude of highpass filtered stimulation artifact recorded on shielded μLED

optoelectrodes. (**f**) Mean waveforms of stimulation artifact recorded on shielded μLED optoelectrodes.

LED drive signal with resulting LED surface irradiance of 75 mW mm^{-2} was used. (**g**) Comparison of mean

peak-to-peak magnitudes of highpass filtered stimulation artifact recorded on the shielded (green) and

non-shielded (red) μLED optoelectrodes. Error bars indicate one standard deviation. (**h**) Mean highpass

filtered waveforms whose mean peak-to-peak magnitudes are shown in part **g**, inside the rectangle with

black dashed lines. Shaded regions show one standard deviation away from the mean. Mean (± SD)

peak-to-peak magnitudes are 2477.8 (± 1733.83) for non-shielded μLED optoelectrodes (n = 75) and

474.6 (± 146.26) for shielded μLED optoelectrodes (n = 67). Results of statistical tests are provided in

Supplementary Table 2.

Figure 3: Eliminated PV-induced artifact. (**a**) Peak-to-peak magnitude of highpass filtered stimulation artifact recorded on shielded μLED optoelectrodes with different substrate doping densities. Data from channels corresponding to all electrodes on the shank on which an LED was turned on are plotted. Boxes indicate interquartile ranges, white lines medians, whiskers non-outlier extreme values, and black x marks outliers. (**b**) Comparison of mean peak-to-peak magnitude of highpass filtered stimulation artifact whose distribution is shown in part **a**. Error bars indicate one standard deviation. (**c**) Mean highpass filtered waveforms whose mean peak-to-peak magnitudes are shown in part **b**, inside the rectangle with black dashed lines. Shaded regions show one standard deviation away from mean. The mean (± SD) peak-to-peak magnitudes are 569.33 (± 129.00), 474.59 (± 146.26), and 146.05 (± 143.40) μVpp for devices with FZ-Si substrate (n = 124), p⁻-Si substrate (n = 67), and p⁺-Si substrate (n = 151), respectively. Results of statistical tests are provided in Supplementary Table 2.

Figure 4: Location dependence of residual artifact.

(**a**) Schematic illustration of the tip of shielded μLED optoelectrode. (**b**) Peak-to-peak magnitude of

highpass filtered stimulation artifact recorded on shielded μLED optoelectrodes with different substrate

doping densities. Data from channels corresponding to electrodes on the shank on which an LED was

turned on are plotted. LED drive signal with resulting LED surface irradiance of 75 mW mm^{-2} was used.

Boxes indicate interquartile ranges, white lines medians, whiskers non-outlier extreme values, and black

x marks outliers. (**c**) Mean waveforms of stimulation artifact recorded on the shielded μLED

optoelectrodes with different substrate doping densities, from channels that correspond to electrodes

on different locations on the tips. LED drive signal with resulting LED surface irradiance of 75 mW mm^{-2}

was used. (**d**) Magnified view of the region inside the rectangle with the black dashed lines on part **a**.

The distances between the center of the interconnects and the center of an LED are shown. (**e**) Peak-to-

peak magnitudes of highpass filtered stimulation artifact recorded from different channels on shielded

μLED optoelectrodes with heavily boron-doped silicon substrate (miniSTAR optoelectrodes). LED drive

signal with resulting LED surface irradiance of 75 mW mm^{-2} was used. Results of statistical tests are

provided in Supplementary Table 2.

Figure 5: Effect of transient pulse shaping on residual artifact.

(**a**) Schematic illustration of the tip of miniSTAR µLED optoelectrodes. Locations of the electrodes and interconnects from which the signals were recorded are indicated with rectangles with bold black lines and black arrowheads, respectively. (**b**) Mean peak-to-peak magnitude of highpass filtered stimulation artifact recorded from the channels indicated in part **a** for two different low-level voltages (V_{low} = 0 V and V_{low} = 2.8 V). High-level voltage of 3.5 V was used. X coordinates indicate the 10 - 90 % rise time of the pulse, and error bars indicate one standard deviation (n = 35). (**c**) Mean waveforms of recorded stimulation artifact, whose mean peak-to-peak magnitudes are shown inside the polygon with dashed lines in part **b**, and their input voltage signals. Stimulation artifact resulting from an input voltage signal is indicated with the same color. (**d**) Peak-to-peak magnitudes of highpass filtered stimulation artifact for a few selected conditions whose means are shown in part **b**. Boxes indicate interquartile ranges, white lines medians, and whiskers extreme values. Mean (± SD) peak-to-peak magnitudes are 535.80 (± 182.94), 173.99 (± 55.76), 111.92 (± 39.55), and 46.53 (± 11.33), from left to right. Results of statistical tests are provided in Supplementary Table 2.

Figure 6: Stimulation-artifact-free *in vivo* opto-electrophysiology.

(**a**) Schematic illustration of the location of implanted miniSTAR μLED optoelectrode inside the brain.

The shank from which the data presented in parts c-h were collected is highlighted with a rectangle with

dashed lines. (**b**) Schematic illustration of the tip of the miniSTAR optoelectrode. (**c**) Mean waveforms of

stimulation artifact recorded on miniSTAR optoelectrodes, from channels that correspond to the

electrodes on different locations on the tips. LED drive signal with resulting LED surface irradiance of 3

mW mm^{-2} at the surface of the LED (radiant flux of 460 nW) was used. (**d**) Traces of the recorded signals

and the raster plots of some sorted spikes. Strong light-induced activities and lack of stimulation artifact

on all the recording channels are shown. (**e**) Peristimulus time histograms of one of the identified cells

whose spikes are highlight in red color in part **d**. (**f**) Magnified view of the signal recorded from Site 7

and the signals provided to the LEDs inside the region highlighted with a rectangle with black dashed

line in part **d**. Note that the spike is not masked by either the offset of stimulation at site 1 or the onset

of stimulation at site 3. (**g**) Magnified view of the spike inside the region highlighted with a rectangle

with black dashed line in part **f**, overlaid on top of waveforms of ten spontaneous spikes from the same

neuron. (**h**) Autocorrelogram of the spikes of the highlighted cell.

References

Buzsaki, G. *et al.* Tools for Probing Local Circuits: High-Density Silicon Probes Combined with Optogenetics. *Neuron* **86**, 92-105, (2015).
Anikeeva, P. *et al.* Optetrode: a multichannel readout for optogenetic control in freely moving mice. *Nat Neurosci* **15**, 163-U204, (2012).
Lu, C. *et al.* Polymer Fiber Probes Enable Optical Control of Spinal Cord and Muscle Function In Vivo. *Adv Funct Mater* **24**, 6594-6600, (2014).
Lee, J., Ozden, I., Song, Y. K. & Nurmikko, A. V. Transparent intracortical microprobe array for simultaneous spatiotemporal optical stimulation and multichannel electrical recording. *Nat Methods* **12**, 1157-+, (2015).
Zhang, J. Y. *et al.* Integrated device for optical stimulation and spatiotemporal electrical recording of neural activity in light-sensitized brain tissue. *J Neural Eng* **6**, (2009).
Kampasi, K. *et al.* Fiberless multicolor neural optoelectrode for in vivo circuit analysis. *Sci Rep-Uk* **6**, (2016).
Royer, S. *et al.* Multi-array silicon probes with integrated optical fibers: light-assisted perturbation and recording of local neural circuits in the behaving animal. *Eur J Neurosci* **31**, 2279-2291, (2010).
Schwaerzle, M., Paul, O. & Ruther, P. Compact silicon-based optrode with integrated laser diode chips, SU-8 waveguides and platinum electrodes for optogenetic applications. *J Micromech Microeng* **27**, (2017).
Stark, E., Koos, T. & Buzsaki, G. Diode probes for spatiotemporal optical control of multiple neurons in freely moving animals. *J Neurophysiol* **108**, 349-363, (2012).
Wu, F. *et al.* An implantable neural probe with monolithically integrated dielectric waveguide and recording electrodes for optogenetics applications. *J Neural Eng* **10**, (2013).
Wu, F. *et al.* Monolithically Integrated mu LEDs on Silicon Neural Probes for High-Resolution Optogenetic Studies in Behaving Animals. *Neuron* **88**, 1136-1148, (2015).
Wise, K. D. & Angell, J. B. Low-Capacitance Multielectrode Probe for Use in Extracellular Neurophysiology. *Ieee T Bio-Med Eng* **Bm22**, 212-219, (1975).
Wise, K. D. *et al.* Microelectrodes, microelectronics, and implantable neural microsystems. *P Ieee* **96**, 1184-1202, (2008).
Wagenaar, D. A. & Potter, S. M. Real-time multi-channel stimulus artifact suppression by local curve fitting. *J Neurosci Meth* **120**, 113-120, (2002).
Zhou, A., Johnson, B. C. & Muller, R. Toward true closed-loop neuromodulation: artifact-free recording during stimulation. *Curr Opin Neurobiol* **50**, 119-127, (2018).
McDonough, R. N., Whalen, A. D. & Ebsco. *Detection of signals in noise*. 2nd ed. edn, Vol. San Diego : (Academic Press, 1995).
Watkins, P. T., Santhanam, G., Shenoy, K. V. & Harrison, R. R. Validation of adaptive threshold spike detector for neural recording. *P Ann Int Ieee Embs* **26**, 4079-4082, (2004).
Fernandez-Ruiz, A. *et al.* Long-duration hippocampal sharp wave ripples improve memory. *Science* **364**, 1082-1086, (2019).
Grosenick, L., Marshel, J. H. & Deisseroth, K. Closed-Loop and Activity-Guided Optogenetic Control. *Neuron* **86**, 106-139, (2015).
Ayling, O. G. S., Harrison, T. C., Boyd, J. D., Goroshkov, A. & Murphy, T. H. Automated light-based mapping of motor cortex by photoactivation of channelrhodopsin-2 transgenic mice. *Nat Methods* **6**, 219-224, (2009).
Budai, D. *et al.* A novel carbon tipped single micro-optrode for combined optogenetics and electrophysiology. *PLoS One* **13**, e0193836, (2018).

Cardin, J. A. *et al.* Targeted optogenetic stimulation and recording of neurons in vivo using cell-type-specific expression of Channelrhodopsin-2. *Nat Protoc* **5**, 247-254, (2010).

Han, X. *et al.* Millisecond-Timescale Optical Control of Neural Dynamics in the Nonhuman Primate Brain. *Neuron* **62**, 191-198, (2009).

Khurram, A. & Seymour, J. P. Investigation of the photoelectrochemical effect in optoelectrodes and potential uses for implantable electrode characterization. *Conf Proc IEEE Eng Med Biol Soc* **2013**, 3032-3035, (2013).

Laxpati, N. G. *et al.* Real-time in vivo optogenetic neuromodulation and multielectrode electrophysiologic recording with NeuroRighter. *Front Neuroeng* **7**, 40, (2014).

Kampasi, K. *et al.* Dual color optogenetic control of neural populations using low-noise, multishank optoelectrodes. *Microsyst Nanoeng* **4**, (2018).

Kim, K. *et al.* GaN-on-Si mu LED optoelectrodes for high-spatiotemporal-accuracy optogenetics in freely behaving animals. *Int El Devices Meet*, (2016).

Jun, J. J. *et al.* Fully integrated silicon probes for high-density recording of neural activity. *Nature* **551**, 232-+, (2017).

Mikulovic, S. *et al.* On the photovoltaic effect in local field potential recordings. *Neurophotonics* **3**, (2016).

Neto, J. P. *et al.* Does Impedance Matter When Recording Spikes With Polytrodes? *Front Neurosci-Switz* **12**, (2018).

Scholvin, J. *et al.* Close-Packed Silicon Microelectrodes for Scalable Spatially Oversampled Neural Recording. *IEEE Trans Biomed Eng* **63**, 120-130, (2016).

Wise, K. D., Angell, J. B. & Starr, A. An Integrated-Circuit Approach to Extracellular Microelectrodes. *Ieee T Bio-Med Eng* **Bm17**, 238-+, (1970).

Fossum, J. G. & Lee, D. S. A physical model for the dependence of carrier lifetime on doping density in nondegenerate silicon. *Solid-State Electronics* **25**, 741-747, (1982).

Ross, B. *Survey of Literature on Minority Carrier Lifetimes in Silicon and Related Topics: Lifetime Factors in Silicon*. (ASTM International, 1980).

Pachitariu, M., Steinmetz, N., Kadir, S., Carandini, M. & Kenneth D., H. Kilosort: realtime spike-sorting for extracellular electrophysiology with hundreds of channels. *bioRxiv*, 061481, (2016).

Desai, S. A., Rolston, J. D., Guo, L. & Potter, S. M. Improving impedance of implantable microwire multi-electrode arrays by ultrasonic electroplating of durable platinum black. *Front Neuroeng* **3**, 5, (2010).

Whalen, J. J., Weiland, J. D. & Searson, P. C. Electrochemical deposition of platinum from aqueous ammonium hexachloroplatinate solution. *J Electrochem Soc* **152**, C738-C743, (2005).

Boehler, C., Oberueber, F., Schlabach, S., Stieglitz, T. & Asplund, M. Long-Term Stable Adhesion for Conducting Polymers in Biomedical Applications: IrOx and Nanostructured Platinum Solve the Chronic Challenge. *Acs Appl Mater Inter* **9**, 189-197, (2017).

Venkatraman, S. *et al.* In Vitro and In Vivo Evaluation of PEDOT Microelectrodes for Neural Stimulation and Recording. *Ieee T Neur Sys Reh* **19**, 307-316, (2011).

Xiao, Y. H., Cui, X. Y. & Martin, D. C. Electrochemical polymerization and properties of PEDOT/S-EDOT on neural microelectrode arrays. *J Electroanal Chem* **573**, 43-48, (2004).

Larson, J., Wong, D. & Lynch, G. Patterned stimulation at the theta frequency is optimal for the induction of hippocampal long-term potentiation. *Brain Res* **368**, 347-350, (1986).

Gunaydin, L. A. *et al.* Ultrafast optogenetic control. *Nat Neurosci* **13**, 387-392, (2010).

Klapoetke, N. C. *et al.* Independent optical excitation of distinct neural populations. *Nat Methods* **11**, 338-346, (2014).

Hashimoto, T., Elder, C. M. & Vitek, J. L. A template subtraction method for stimulus artifact removal in high-frequency deep brain stimulation. *J Neurosci Meth* **113**, 181-186, (2002).

Acknowledgements

The work has been supported by NIH 1-U01-NS090526-01, NSF 1545858, NSF 1707316, NIH 1-R01-MH107396-01, and NIH 1-U01-NS090583-01.

Author Information

Affiliations

Department of Electrical Engineering and Computer Science, University of Michigan, Ann Arbor, Michigan 48109, USA

Kanghwan Kim, Mihály Vöröslakos, John P. Seymour, Kensall D. Wise & Euisik Yoon

Neuroscience Institute, Langone Medical Center, New York University, New York, NY, 10016

Mihály Vöröslakos & György Buzsáki,

Author contributions

K. K. and E. Y. worked together on conceptual design of minimal-stimulation-artifact (miniSTAR) μLED optoelectrodes. K. K. designed, fabricated, and assembled μLED optoelectrodes; conducted CAD simulations; conducted *in vitro* characterizations; and analyzed recorded data. M. V. conducted *in vivo* experiments with K. K. and processed recorded neuronal signals. J. P. S., K. D. W., G. B. and E. Y. supervised the study. K.K., M. V., and E. Y. wrote the manuscript. All authors discussed the results and commented and edited the manuscript.

Corresponding author

Correspondence to Euisik Yoon