Glycerol-driven Denitrataion: Process Kinetics, Microbial Ecology, and Operational Controls

AUTHOR NAMES: *Matthew P. Baideme*,^{a,#} *Chenghua Long*,^a *Luke T. Plante*,^{a,b} *Jeffrey A. Starke*,^{b,1} *Michael A. Butkus*,^b and *Kartik Chandran*^{a,*}

AUTHOR AFFILIATIONS:

^a Department of Earth and Environmental Engineering, Columbia University, New York, NY 10027, U.S.A.

^b Department of Geography and Environmental Engineering, United States Military Academy, West Point, NY 10996, U.S.A.

¹ Present address: Opus College of Engineering, Marquette University, Milwaukee, WI 53201, U.S.A.

[#] Co-corresponding author: Department of Earth and Environmental Engineering, Columbia University, 500 W. 120th St., New York, NY 10027. Email: mpb2177@columbia.edu.

^{*} Co-corresponding author: Department of Earth and Environmental Engineering, Columbia University, 500 W. 120th St., New York, NY 10027. Email: kc2288@columbia.edu. Phone: 212.854.9027. Fax: 212.854.7081.

ABSTRACT: Denitrataion, the selective reduction of nitrate to nitrite, is a novel process when coupled with anaerobic ammonium oxidation (anammox) could achieve resource-efficient biological nitrogen removal of ammonium- and nitrate-laden waste streams. Using a

fundamentally-based, first principles approach, this study optimized a stoichiometrically-limited, glycerol-driven denitrification process and characterized mechanisms supporting nitrite accumulation with results that aligned with expectations. Glycerol supported selective nitrate reduction to nitrite and near-complete nitrate conversion, indicating its viability in a denitrification system. Glycerol-supported specific rates of nitrate reduction (135.3 mg-N/g-VSS/h) were at least one order of magnitude greater than specific rates of nitrite reduction (14.9 mg-N/g-VSS/h), potentially resulting in transient nitrite accumulation and indicating glycerol's superiority over other organic carbon sources in denitrification systems. pH and ORP inflection points in nitrogen transformation assays corresponded to maximum nitrite accumulation, indicating operational setpoints to prevent further nitrite reduction. Denitrification conditions supported enrichment of *Thauera* sp. as the dominant genus. Stoichiometric limitation of influent organic carbon, coupled with differential nitrate and nitrite reduction kinetics, optimized operational controls, and a distinctively enriched microbial ecology, was identified as causal in glycerol-driven denitrification.

KEYWORDS: partial denitrification; denitrification; glycerol; short-cut biological nitrogen removal; first-principles approach

1. Introduction

Conventional biological nitrogen removal (BNR), including energy and chemical-intensive nitrification and denitrification, is traditionally used to treat ammonium-laden (NH_4^+) waste streams. The advent of engineered processes that achieve oxidation of NH_4^+ to nitrite (NO_2^-), termed nitrification, combined with denitrification (reduction of NO_2^- to nitrogen gas (N_2))

or anaerobic ammonium oxidation (anammox) represent short-cut BNR alternatives to conventional BNR approaches. Such short-cut BNR processes can provide reductions in chemical (external carbon for denitrification and alkalinity for nitrification) and energy use (aeration for nitrification), driving the desire for NO_2^- accumulation within these processes.

Alternatively, waste streams containing concomitantly high concentrations of NH_4^+ and nitrate (NO_3^-), such as those resulting from fertilizer¹ and explosives manufacturing,^{2,3} provide similar energy and chemical reduction opportunities through distinct short-cut BNR processes. A particularly effective pathway for treating waste streams containing both NH_4^+ and NO_3^- is through heterotrophic⁴⁻⁹ or autotrophic¹⁰ denitrification (selective reduction of NO_3^- to NO_2^-) coupled with downstream anammox. A combined denitrification-anammox system used to treat waste streams containing equal concentrations of NH_4^+ and NO_3^- would theoretically reduce aeration energy requirements by 100% and COD requirements by 80% compared to treatment of the same waste stream using conventional BNR. Recent studies⁴⁻⁹ on heterotrophic denitrification have focused on performance in lab-scale sequencing batch reactors (SBRs) driven by acetate, methanol, glucose, and sludge fermentation liquid due to the lack of sufficient readily biodegradable chemical oxygen demand (COD) in typical waste streams. These studies have primarily been observational in nature, with particular emphasis placed on empirically identifying parameters and conditions that potentially contributed to NO_2^- accumulation, such as influent COD:N ratios, pH, ORP, and loading rates. Stoichiometric limitation of influent COD:N ratios, specifically, has been shown to influence endpoint nitrogen speciation.¹¹ Various parameter combinations were optimized, denoted by the observation of stable NO_3^- -to- NO_2^- conversion ratios as high as 90% during steady-state studies.⁶

The selection of an external COD source to drive denitrification is critical when attempting to maximize NO_2^- accumulation. Traditionally, methanol has been one of the most widely used external COD sources for denitrification due to its low cost and wide availability.¹² NO_2^- accumulation has proven difficult with methanol due to methanol dehydrogenase's direct delivery of electrons to cytochrome *c* and proximal to NO_2^- reductase as opposed to distribution solely through the ubiquinol pool to NO_3^- reductase similar to other carbon sources.^{13–15} The unique electron delivery locations during methanol oxidation within the respiratory denitrification chain potentially contribute to concomitant NO_3^- and NO_2^- reduction.

Several water resource recovery facilities are switching to glycerol due to the operational and safety risks associated with methanol.¹² Glycerol is similar in cost to methanol and less expensive than ethanol and acetate,^{16–18} is available as a waste or byproduct,^{19,20} and has no known inhibitory effects on the anammox process, unlike methanol.²¹ NO_2^- accumulation during glycerol supplementation was also anecdotally observed in full-scale treatment plants resulting in unintentional enrichment of anammox on the produced NO_2^- .²² Nevertheless, to fully realize the operating benefits that a denitrification-anammox system could offer, it is imperative for the parameters and conditions leading to NO_2^- accumulation in a glycerol-driven denitrification system to be systematically identified, defined, and addressed in relation to reactor operating strategies.

Accordingly, the overarching goals of this study were to use a fundamentally-based, first principles approach to characterize the process kinetics, nitrogen conversion efficiencies, and microbial ecology of a glycerol-fed denitrification process, and identify concomitant reactor operating strategies. The specific objectives were to (1) control selective conversion of NO_3^- to NO_2^- through stoichiometric limitation of influent glycerol dose, (2) quantify the rates of NO_3^-

reduction relative to rates of NO_2^- reduction and understand their impact on the selective accumulation of NO_2^- , (3) elucidate the microbial community structure under varied carbon-loading levels in a functional glycerol-driven denitrification process, and (4) identify operational controls and reactor operating strategies to maximize denitrification rates and efficiencies.

2. Materials and Methods

2.1. Experimental Set-up and Reactor Operation

A lab-scale SBR with a working volume, $V=12$ L, was operated at room temperature ($22\pm 2^\circ\text{C}$) for a period of 232 d. The SBR was operated at a hydraulic retention time (HRT) of 1 d, utilizing 4 cycles per day with each cycle consisting of a 90-min anoxic feed and react period, a 180-min anoxic react period, a 50-min settling period, and a 40-min decant period. SBR feed contained 100.0 mg/L NO_3^- -N as the terminal electron acceptor to simulate the influent of a high NO_3^- -containing waste stream typical of a fertilizer¹ or explosives² manufacturing facility, 25.0 mg/L NH_4^+ -N (to support assimilation), and macro and trace nutrients (Table S1). pH was controlled automatically at 7.50 ± 0.05 using 0.5 M HCl and 1.0 M NaHCO_3 via a chemical dosing pump (Etatron D.S., Italy). Sludge wasting was controlled daily at the end of the anoxic feed and react period following COD exhaustion to maintain a solids retention time (SRT) of 3 d. Glycerol, diluted to a 15% solution by volume, served as the external COD source and was provided to meet influent COD: NO_3^- -N ratios from 2.4:1 to 5.0:1. Glycerol was fed at the end of the anoxic feed and react period so that examined influent COD: NO_3^- -N ratios were met during each cycle. Upon transitioning to each influent COD: NO_3^- -N ratio tested, a stabilization period of 4 x SRT was allowed prior to assessing performance relative to other conditions. Sequencing

and timing of SBR cycles and daily solids wasting was controlled and maintained by peristaltic pumps (Masterflex, IL) using electronic timers (ChronTrol Corporation, CA).

2.2. Sample Collection and Wastewater Quality Analysis

All analytical procedures employed were in accordance with Standard Methods.²³ Aqueous-phase samples were withdrawn during the decant period of the reactor cycle and concurrently from the influent for chemical species analysis after centrifugation (8,000 x G, 10 min, 4-8°C) to remove cells and cell debris. NO_3^- and NH_4^+ were measured using ion selective electrodes (Thermo Fisher Scientific, MA). NO_2^- concentration was measured via diazotization and colorimetry.²³ The fraction of influent NO_3^- lost to nitrogenous gases was determined via mass balance on nitrogen. Centrifuged aqueous-phase samples were filtered using 0.20 μm syringe filters (A Chemtek, MA) and stored at -20°C. Dionex ICS-2100 ion chromatography using a Dionex IonPac AS-18 IC column (Thermo Fisher Scientific, MA) was used to confirm ion selective electrode and colorimetric measurements of NO_3^- and NO_2^- concentrations, respectively. Similarly, a Dionex IonPac AS-14 IC column (Thermo Fisher Scientific, MA) was used to quantify volatile fatty acid production during unbuffered *ex situ* batch kinetic assays. Separate aqueous-phase samples were extracted at the end of the anoxic react period and during the decant period of the reactor cycle to assess total biomass concentrations in the reactor and effluent, respectively, for SRT control. Aqueous-phase samples taken during the decant period were centrifuged (8,000 x G, 10 min, 4-8°C) and filtered using 0.45 μm syringe filters (A Chemtek, MA) to assess remaining soluble COD (sCOD) concentrations (Hach Chemical Company, CO). Biomass concentrations were approximated by subtracting sCOD measurements from total COD measurements to determine particulate COD (pCOD) (Hach Chemical

Company, CO).²⁴ Additional aqueous-phase samples taken just prior to the end of the anoxic react period were centrifuged (8,000 x G, 10 min, 4-8°C), supernatant was discarded, and cell pellets were preserved at -80°C for subsequent DNA extraction and 16S rRNA gene sequencing.

2.3. Feeding Strategy Experiments

Two feeding strategies were tested to maximize NO₂⁻ accumulation. A semi-continuous feeding strategy delivered NO₃⁻-containing SBR feed and glycerol continuously for the first 75 and 72 min, respectively, of the anoxic feed and react period (Fig. S1). A pulse feeding strategy delivered a pulse of NO₃⁻-containing SBR feed and glycerol every 45 min for the first 270 min of the SBR cycle (Fig. S1). Feeding rates were controlled to maintain equivalent mass loading rates of NO₃⁻ and glycerol and influent COD:NO₃⁻-N ratios for the two feeding strategies.

2.4. Batch kinetic assays

Batch assays, *in situ* (within the SBR) and *ex situ*, were conducted to measure extant process kinetics and optimize operational controls, including batch duration, pH, and ORP. *In situ* assays followed previously described sampling collection and chemical analysis procedures. Aqueous-phase samples were obtained from the primary SBR at steady-state over the course of a single 360-min reactor cycle. *Ex situ* assays were carried out in an anoxic, sealed, spinner flask batch vessel with a working volume, V=1 L, at room temperature (22±2°C). Mixed liquor was taken from the primary SBR at steady-state during the feed and react period, washed 4 times using SBR feed without NO₃⁻, and supernatant was discarded. Prior to extant kinetic batch assays, the medium was buffered to pH 7.50 using 0.5 M HCl and 1.0 M NaHCO₃ and N₂ gas was sparged until dissolved oxygen (DO) levels were equal to 0.01 mg/L O₂, or the minimum

practical limit of the InPro 6850i polarographic DO sensor with M300 transmitter (Mettler-Toledo, OH). pH was maintained at pH 7.50±0.05 by manual control. pH optimization batch assays were conducted within normal pH operating ranges (see Supporting Information (SI)). NO₃⁻ and glycerol were dosed to meet the desired initial COD:NO₃⁻-N ratio. NO₃⁻ was dosed at the outset of the experiment (time=0 min) and the biomass was incubated for 30 min prior to the addition of glycerol to ensure that residual nitrogen species and glycerol from the primary SBR remaining in the washed mixed liquor were consumed prior to data collection. pH, ORP, and DO were measured and recorded continuously via an InPro 3253i/SG pH/ORP electrode and an InPro 6850i polarographic DO sensor, respectively, attached to an M300 transmitter (Mettler-Toledo, OH). Following extant kinetic batch assays, linear regression with R²≥95% of NO_x-N species from time points of maximum concentration to minimum concentration for each respective species was performed with pCOD concentrations taken just prior to glycerol input to determine true specific rates of NO₃⁻ reduction (sDNaR) (Eqn. 1) and NO₂⁻ reduction (sDNiR) (Eqn. 2). NO₂⁻ production resulting from NO₃⁻ reduction was not accounted for in the determination of specific rates of NO₂⁻ reduction, yet this remains representative of a true reduction rate. During the time points assessed for each influent COD:NO₃⁻-N ratio, NO₃⁻ removal was complete or near-complete (<3% of initial dose) except at influent COD:NO₃⁻-N=2.5:1 where NO₃⁻ concentration measurements confirmed no continued NO₃⁻ reduction. pCOD measurements were used to determine maximum specific substrate consumption rates (Eqns. 1-2).

$$sDNaR = \left(\frac{1}{X}\right) \left(\frac{\Delta S_{NO_3^-}}{\Delta t}\right) \quad \text{Eqn. 1}$$

$$sDNiR = \left(\frac{1}{X}\right) \left(\frac{\Delta S_{NO_2^-}}{\Delta t}\right) \quad \text{Eqn. 2}$$

Where:

$sDNaR$: maximum specific NO_3^- consumption rate (mg NO_3^- -N/g VSS/h)

$sDNiR$: maximum specific NO_2^- consumption rate (mg NO_2^- -N/g VSS/h)

X : volumetric biomass concentration approximated using pCOD measurements (g VSS/L)

$\frac{\Delta S_{NO_3^-}}{\Delta t}$: volumetric substrate (NO_3^-) consumption rate (mg NO_3^- -N/L/h)

$\frac{\Delta S_{NO_2^-}}{\Delta t}$: volumetric substrate (NO_2^-) consumption rate (mg NO_3^- -N/L/h)

2.5. DNA Extraction, Next-Generation Sequencing of Amplicon Library, and Bioinformatics

DNA was extracted from biomass samples and purified using a QIAamp DNA Mini Kit (Qiagen, Inc., MD). The quality and quantity of DNA were checked using a NanoDrop Lite spectrophotometer (Thermo Fisher Scientific, MA). Barcoded fusion primers with Ion XpressTM sequencing adapters (Thermo Fisher Scientific, MA) and a 16S rRNA bacterial 1055F/1392R universal primer set were applied in each sample for multiplex sequencing. Amplification of genomic DNA targets was performed with iQTM SYBR[®] Green Supermix (Bio-Rad, CA) and purification via Agencourt AMPure XP Reagent (Beckman Coulter, CA). Library quantification was performed with an Agilent DNA 1000 Kit (Agilent, CA). Template preparation with the DNA library followed by Ion Spheres Particle (ISP) enrichment was performed using Ion OneTouch2 (Ion PGM Hi-Q View OT2 Kit). Enriched ISP was loaded onto an Ion Torrent 318 v2 BC chip and run on an Ion Torrent Personal Genome Machine (Ion PGM Hi-Q View Sequencing Kit). Ion Torrent Suite software was used for base calling, signal processing, and

quality filtering (Phred score of >15) of the raw sequences. The 1055F/1392R universal primer set targeted sequences of approximately 350 base pairs (bp). Mothur software was used to initially screen out likely incorrect amplicon sequences with bp lengths more than 50 bp different than the target sequence length.²⁵ AfterQC software was utilized to further delete bad quality reads (Phred score of <20) and trim the tails of reads where quality dropped significantly.²⁶ DADA2 programming via R Studio software was used to produce a table of non-chimeric amplicon sequence variants from the demultiplexed fastq files.²⁷ QIIME2 software was applied in conjunction with the Silva version 132 reference taxonomy for further post-sequencing bioinformatic analysis.²⁸

2.6. Nitrogen Conversion Calculations

Reactor performance was normalized with respect to the influent characteristics. A NO₂⁻ accumulation ratio (NAR) (Eqn. 3) was defined to relate the accumulation of NO₂⁻ to the removal of NO₃⁻.²⁹ A NAR equal to 100% indicated that all NO₃⁻ removed accumulated as NO₂⁻ compared to terminal reduction to N₂ gas, for which the NAR would be 0%.

$$NAR = \left[\frac{(NO_{2,eff}^- - NO_{2,in}^-)}{(NO_{3,in}^- - NO_{3,eff}^-)} \right] \times 100\% \quad \text{Eqn. 3}$$

NO₃⁻ reduction was also classified in terms of a NO₃⁻ reduction ratio (NRR) (Eqn. 4), which normalized the conversion of NO₃⁻ to the influent NO₃⁻ concentration.⁹ A NRR equal to 100% would indicate conversion of all influent NO₃⁻ to any reduced form, while a NRR of 0% would indicate no conversion.

$$NRR = \left[\frac{(NO_{3,inf}^- - N) - (NO_{3,eff}^- - N)}{(NO_{3,inf}^- - N)} \right] \times 100\% \quad \text{Eqn. 4}$$

229

230 3. Results and Discussion

231 3.1. Denitratation Reactor Performance

232 The influent COD:NO₃⁻-N ratio required for glycerol-driven denitrification (NO₃⁻-N to N₂
233 reduction) was thermodynamically³⁰ determined to be 5.9:1 (see SI). This corresponded well
234 with experimentally-determined operational ratios of 4.2:1 to 5.6:1,^{16,20,31} although the lowest
235 reported ratio¹⁶ may not be fully representative as it was determined via *ex situ* batch assays as
236 opposed to steady-state continuous flow bioreactor or SBR operation. Stoichiometric analysis
237 revealed that influent COD:NO₃⁻-N=2.4:1 (see SI) would provide only enough electrons via
238 COD oxidation to reduce NO₃⁻ to NO₂⁻ on a theoretical electron equivalence basis as opposed to
239 full denitrification. Therefore, influent COD:NO₃⁻-N ratios between 2.4:1 and 5.9:1 were
240 referred to as stoichiometrically-limited for the purposes of this study. These calculations form
241 the fundamentally-based foundation to the first principles approach used in this study to conduct
242 and interpret the results of glycerol-driven denitratation presented herein.

243 The utilization of glycerol as the external COD source and electron donor resulted in
244 significant NO₂⁻ accumulation at stoichiometrically-limited influent COD:NO₃⁻-N ratios from
245 2.5:1 to 5.0:1, indicating that the use of glycerol was feasible to sustain a denitratation process.
246 The highest degrees of NO₃⁻ removal and NO₂⁻ accumulation, as a function of influent
247 COD:NO₃⁻-N ratio during steady-state SBR operation, occurred at influent COD:NO₃⁻-N=3.0:1
248 (Fig. 1). This resulted in an average NO₂⁻ accumulation of 60.8±11.5 mg/L NO₂⁻-N (n=10) and
249 NAR of 62%, indicating that 62% of the NO₃⁻ reduced was converted to NO₂⁻ rather than
250 terminally reduced to N₂ gas. Additionally, the NRR was determined to be 96%, indicating that

a majority of the influent NO_3^- was converted leaving only approximately 4% of influent NO_3^- in the effluent (Table 1). Accumulation of NO_2^- at influent COD: NO_3^- -N=2.8:1 compared to influent COD: NO_3^- -N=3.0:1 was not significantly different ($p=0.49$, $\alpha=0.05$, $n=10$). Substantial NO_3^- accumulation occurred at influent COD: NO_3^- -N=2.8:1 (31.7 ± 11.4 mg/L NO_3^- -N, $n=11$), signifying that this ratio was less operationally optimal compared to influent COD: NO_3^- -N=3.0:1. The observed NO_3^- accumulation at influent COD: NO_3^- -N=2.5:1 and 2.8:1 may be due to lower COD-supported biomass concentrations leading to reduced denitrification rates. However, effluent sCOD concentrations were negligible signifying that glycerol was nearly completely consumed (sCOD and biomass concentration data not shown). *In situ* performance profiles (Fig. 2) did not show significant endogenous denitrification, potentially indicating that COD uptake and storage was minimal. Rather, the observed NO_3^- accumulation in these cases indicated that the influent COD: NO_3^- -N was not sufficient,⁹ potentially due to unrealized COD requirements for cell maintenance and synthesis³² or additional demand by fully denitrifying microorganisms remaining in the microbial community. Therefore, influent COD: NO_3^- -N=3.0:1 was selected as the optimal ratio due to the similar NO_2^- accumulation to influent COD: NO_3^- -N=2.8:1 coupled to less than 4% of the influent NO_3^- remaining in the effluent. The high sensitivity at influent COD: NO_3^- -N<3.0:1 highlighted significant implication for accurate system operation and control. A minimal reduction in influent COD: NO_3^- -N ratio from 3.0:1 to 2.8:1 yielded a sevenfold increase in effluent NO_3^- , signifying that strict control of the glycerol-driven denitrification system must be maintained. To this end, online dosing control¹⁷ based on appropriate signals of reactor performance seems necessary to maximize concomitant NO_3^- -N conversion selectively to NO_2^- during partial denitrification.

Analysis of variance (ANOVA) across the influent COD:NO₃⁻-N ratios identified a statistically significant difference in NAR ($p=4.8 \times 10^{-11}$, $\alpha=0.05$, $n=38$) with a decrease from 62% to 11% as the influent COD:NO₃⁻-N ratio approached that for glycerol-driven denitrification (5.9:1; see SI). Further Holm-Sidak post-hoc multiple comparison analysis indicated that the significant difference in NAR was primarily caused by the expectedly lower NAR at influent COD:NO₃⁻-N=5.0:1 ($p<9.7 \times 10^{-5}$ for all comparisons, $\alpha=0.05$; Table S2). The decrease in NAR from influent COD:NO₃⁻-N=4.0:1 to 5.0:1 was most likely attributable to excess available COD.

Previous studies^{4,6} observed that varying the influent COD:NO₃⁻-N ratio had a negligible effect on the NAR determined at the point of maximum NO₂⁻ accumulation during *ex situ* batch experiments, while a separate batch study³³ concluded that the COD source, as opposed to the influent COD:NO₃⁻-N ratio, impacted the NAR more readily. In contrast, another separate batch study⁷ concluded that NO₂⁻ accumulation was influenced by both the COD source and COD dosing. While insightful, the utility of these results^{4,6,7} to guide steady-state denitrification processes is limited as these studies failed to acclimate their batch experiment seed sludge to the conditions being investigated, which likely contributed to their discrepancy with the current study. Despite investigating the impact of various influent COD:NO₃⁻-N ratios, Ge et al.⁷ utilized a fully denitrifying inoculum, whereas Du et al.⁶ inoculated batch experiments assessing various influent COD:NO₃⁻-N ratios with a microbial community acclimated to a single stoichiometrically-limited influent COD:NO₃⁻-N ratio. Both seed sludges likely contained phenotypes with NO₂⁻ accumulation capabilities different than those expected following acclimation to the investigated conditions. Cao et al.⁴ did not report conditions of their batch inoculum.

In an improvement over these previous efforts, our current study utilized a sludge stabilization and acclimation period of 4 x SRT following influent COD:NO₃⁻-N ratio changes. This intentionally allowed the microbial community to adapt to the influent COD:NO₃⁻-N ratio being investigated. In doing so, it was observed that the influent COD:NO₃⁻-N ratio had similar impacts on NAR during both steady-state operation (Fig. 1) and *ex situ* batch assays, with NO₂⁻ accumulation decreasing as influent COD:NO₃⁻-N ratios increased (Fig. S2).

In comparison to other steady-state operation studies^{6,9,34} using primarily sodium acetate as the external COD source, glycerol-driven NARs were at least 10% lower (Table 1). While most reported acetate-driven denitrification NARs were greater than 80%, glycerol-driven denitrification yielded NARs less than 70%. These respective acetate-driven steady-state studies^{6,9,34} were deemed reasonable comparisons due to similar COD dosing regimens and results were reported for study periods sufficient in length to assume microbial community acclimation to and stabilization at the studied conditions. Despite this, the assessment of reactor performance based solely upon reported NARs can be misleading as the index does not account for complete or other conversion of influent NO₃⁻. Thus, NAR=100% does not necessarily indicate that all influent NO₃⁻ was converted. Several studies,^{4-6,34} however, reported NRRs of nearly 100% that when coupled with a NAR approaching 100% indicated near-perfect denitrification performance (Table 1). It follows then that optimal performance in the current study occurred at influent COD:NO₃⁻-N=3.0:1 with NAR=62% and NRR=96%. The inability of glycerol to achieve similar efficiency to acetate- or fermentate-driven denitrification is not currently understood. Possible explanations include a greater intracellular carbon and microbial energy storage mechanism during low substrate availability,^{35,36} the COD-source supported enrichment of a microbial consortium with a greater abundance of true denitrifiers,³⁷ an

inefficient metabolism in support of denitrification due to a less direct assimilability of glycerol, or the downstream delivery of electrons on the electron transport chain similar to methanol.^{14,15}

Effluent sCOD measurements, as an estimation of residual glycerol concentration, averaged 9.4 ± 8.8 mg/L COD (n=29) across all influent COD:NO₃⁻-N ratios assessed. The *ca.* 96% average decrease from influent to effluent sCOD indicates that nearly all of the glycerol was consumed, and that reactor cycle duration was adequate for COD consumption.

A likely contributing factor to the need for a higher than the theoretical influent COD:NO₃⁻-N ratio (see SI) was an incomplete enrichment for a solely denitrifying or progressive onset³⁸ phenotype-dominated microbial community. The presence of microorganisms that express a complete denitrification metabolic pathway or those that exhibit a rapid, complete onset of denitrification genes³⁸ would impose a competitive demand on influent COD, thus decreasing its availability for selective reduction of NO₃⁻ to NO₂⁻. This additional COD demand would result in a high NRR but low NAR, or significant gaseous-N products with limited NO₂⁻ accumulation, which was supported by the results herein (Table 1).

3.2. Process Kinetics

Notably, extant kinetic analysis indicated that transient NO₂⁻ accumulation at all influent COD:NO₃⁻-N ratios assessed was potentially due to at least one order of magnitude greater specific rates of NO₃⁻ reduction compared to the specific rates of NO₂⁻ reduction driven by glycerol (Table 2).³⁹ Observed performance at influent COD:NO₃⁻-N>3.0:1 (Fig. S2) also supported this assertion as the maximum NO₂⁻ accumulated never equaled the initial NO₃⁻ concentration, indicating that there was concomitant reduction of NO₃⁻ and NO₂⁻. However, performance at influent COD:NO₃⁻-N=3.0:1 resulted in near-complete selective reduction of

NO₃⁻ to NO₂⁻ prior to terminal reduction to N₂ gas (Fig. S2). It should be emphasized that the kinetic profiles in Fig. S2 were obtained from acclimated biomass from individual SBRs operated for at least 4 x SRT at each influent COD:NO₃⁻-N ratio.

In general, measured specific rates of NO₃⁻ reduction and $\mu_{\max}$ values were higher than those previously reported for glycerol-driven full denitrification studies (Table 2) and may be due to differences in the microbial community that was selected for by stoichiometric limitation during our current denitrification-specific study. Glycerol-driven specific rates of NO₃⁻ reduction values were nearly double those reported for acetate-driven systems at similar influent COD:NO₃⁻-N ratios, but slightly lower than those observed in an experiment utilizing a combination of external COD sources garnered from sodium acetate and endogenous carbon in a domestic wastewater stream (Table 2). The ratios of sDNaR:sDNiR achieved in this study with glycerol across different influent COD:NO₃⁻-N values were also higher than previously reported with acetate (Table 2). This difference may be due to variations in the direct assimilability of each COD source with more assimilable COD sources such as glycerol or endogenous carbon in these cases supporting greater specific rates of NO₃⁻ reduction,³² or the COD source-supported microbial community.

3.3. NO₂⁻ Accumulation through the Management of Operational Controls

3.3.1. Denitrification Control via Batch Duration

Batch duration was identified as an effective process control parameter to maximize NO₂⁻ accumulation. The duration of the anoxic feed and react period could be shortened to achieve comparable or improved performance. NO₂⁻ concentrations decreased following peaks of NO₂⁻ accumulation at higher influent COD:NO₃⁻-N ratios (4.0:1, 5.0:1; Fig. 2). This decrease was not

observed at influent COD:NO₃⁻-N=3.0:1, indicating that excess COD remained following completion of denitrification at higher ratios. Despite minimal NO₂⁻ reduction following peak NO₂⁻ accumulation at influent COD:NO₃⁻-N=2.5:1, overall performance remained low, making this ratio less effective at achieving partial denitrification (Table 1; Fig. 2).

Results generally supported that influent COD:NO₃⁻-N ratios have an inverse relationship with time to maximum NO₂⁻ accumulation during the anoxic react period. Batch duration could be reduced to 150 minutes or less, or the time to maximum NO₂⁻ accumulation (Fig. 2). Subtraction of the feed and react period of the SBR cycle from the reduced batch duration, by extension, would yield an optimal react time equivalent to a continuous flow system's HRT (Fig. 2). The optimal react time is representative of when glycerol is available for NO₃⁻ reduction in both systems. Therefore, the identified optimal react times in our SBR system would be equivalent to HRTs of approximately 30 minutes (COD:NO₃⁻-N=4.0:1 and 5.0:1) to 60 minutes (COD:NO₃⁻-N=2.5:1 and 3.0:1) in continuous flow systems operating at each respective influent COD:NO₃⁻-N ratio.

3.3.2. Denitrification Control via pH and ORP

During unbuffered and non-carbon limited operation (influent COD:NO₃⁻-N≥5.9:1), the denitrification-dominated phase of the denitrification profile exhibited a distinct decrease in the reactor's pH and increase in the ORP until both reached inflection points after which pH increased and ORP decreased (Fig. 3). At this inflection point, NO₃⁻ reduction decelerated due to the depletion of available NO₃⁻ allowing for observable concomitant NO₂⁻ reduction thus decreasing the NAR and negatively impacting the objective of maximizing NO₂⁻ accumulation. Continuous monitoring of pH and ORP could provide an observable real-time control to maximize

denitrification. While feedforward online control of COD dosing tied to influent NO_x loading has proven effective in controlling denitrification,¹⁷ this system requires online NO_x sensors which may not be achievable at all plants due to potentially high capital⁴⁰ and maintenance costs.⁴¹ Rather, denitrification control via pH and ORP observation could provide a backup check or serve as a less costly alternative⁴⁰ with widely available and utilized sensors.

pH and ORP were previously reported as control parameters for denitrification driven by acetate, methanol, endogenous carbon, soybean wastewater, and brewery wastewater.^{6,7,33,42,43} Contrary to the distinct glycerol-driven pH and ORP profile observed in the current study, Ge et al.⁷ and Du et al.⁶ described acetate-driven profiles exhibiting a general increase in pH whereby a “turning point” separated denitrification from denitrification. However, the observed pH profiles obtained experimentally in our study (Fig. 3) are in excellent concurrence with theoretically calculated net production of 0.43 equivalents of acidity per mole NO₃⁻ reduced to NO₂⁻ (Eqn. 5), which supported the observed pH fluctuation profiles.

For completeness, stoichiometry (Eqn. 6) reveals that denitrification should result in a net consumption of 0.36 equivalents of acidity per mole NO₂⁻ reduced to N₂ gas at pH 7.5.

3.3.3. Denitratation Control via Feeding Strategy

The pulse feeding strategy resulted in a statistically significant improvement in denitratation performance ($\alpha=0.05$; $n=8$) over the semi-continuous feeding strategy in both NO_2^- accumulation ($p=0.03$) and NO_3^- reduction ($p=0.0003$), indicating that feeding methodology impacted the performance of the system (Table S3). As both feeding strategies maintained equivalent influent COD: NO_3^- -N ratio per substrate pulse or for the duration of the semi-continuous feeding period, this difference in system performance was thought to be influenced by the temporal distribution of substrate pulses. Those pulses occurring later in the anoxic feed and react period may have limited the time for the biotransformation of NO_3^- to gaseous nitrogen thus allowing for greater NO_2^- accumulation. This is counter to the semi-continuous feeding strategy, where fully denitrifying microorganisms within the microbial community had the full anoxic feed and react period to reduce influent NO_3^- . Therefore, in a continuous-flow BNR process, the spatial location of introducing glycerol could be another factor to promote partial denitratation if possible. Optimizing the dosing location of electron donors is quite widely practiced for increasing the efficiency of COD utilization even for full denitrification in step-feed BNR or Bardenpho configurations.⁴⁴

3.4. Microbial Ecology

Proteobacteria was the most dominant phylum out of 14 identified at all influent COD: NO_3^- -N ratios (Fig. 4a). β -*Proteobacteria* made up at least 73% of the *Proteobacteria* phylum at all influent COD: NO_3^- -N ratios. In a survey of wastewater denitrifying bacterial 16S rDNA sequences retrieved from GenBank, Lu et al.⁴⁵ found that approximately 72% of

prokaryotic microorganisms displaying denitrifying capabilities were taxonomically affiliated with *Proteobacteria*, while β sub-class affiliated microorganisms were typically abundant in denitrifying activated sludge,^{1,45,46} similar to the findings herein.

Within β -*Proteobacteria*, the *Rhodocyclaceae* and *Comamonadaceae* families were identified as those mainly involved in denitrification in activated sludge.^{46,47} Our findings supported this as *Thauera* sp., that belongs to the *Rhodocyclaceae* family within β -*Proteobacteria* was enriched as the most dominant genus with a relative abundance of nearly 80% at influent COD:NO₃⁻-N=3.0:1 (Fig. 4b). *Comamonadaceae* fam. was not found, indicating that their enrichment may not be favored under stoichiometrically-limited conditions imposed herein. Certain *Thauera* spp. strains were characterized according to two distinct regulatory phenotypes,⁴⁸ including the immediate and simultaneous onset of all denitrification genes with no detectable NO₂⁻ accumulation, as well as the progressive and sequential onset of denitrification cascade genes with appreciable NO₂⁻ accumulation.³⁸ Selective pressures were not identified for either, although the selection for progressive onset denitrifiers would be critical to facilitate denitrification. The coupling of a high relative abundance of *Thauera* sp. (Fig. 4b), high NRR, and high NAR (Table 1), with the ability to perform full denitrification when presented with sufficient COD (Fig. S2) indicated that the application of stoichiometric limitation in the influent COD:NO₃⁻-N as a selective pressure may favor the progressive onset over rapid, complete onset phenotype. *Thauera* sp. may represent a key functional microorganism for denitrification systems indicated by its decreasing relative abundances away from the optimal influent COD:NO₃⁻-N (Fig. 4b). Several recent denitrification-specific studies^{4,6,9,49} further supported this argument with reported *Thauera* sp. relative abundances from 55% to 73% under limited influent COD:NO₃⁻-N ratios with acetate as the external COD source

despite different seed sludges. In comparison, acetate-driven full denitrification studies reported no more than 12% relative abundance of *Thauera* sp.^{46,50} Therefore, the application of a stoichiometrically-limited influent COD:NO₃⁻-N ratio as a selective pressure in a denitrification system may impart a stronger impact on the denitrifying community structure than previously recognized.

4. Conclusions

Denitrification, with downstream anammox processes, offers chemical and energy reductions through resource-efficient BNR of NH₄⁺ and NO₃⁻-laden waste streams. A fundamentally-based, first-principles approach was used to propose an influent COD:N ratio and other operating parameters that would promote denitrification and experimental results aligned with expectations. Glycerol supported the process kinetics and microbial ecology necessary to selectively convert NO₃⁻ to NO₂⁻ in denitrification systems. Process control strategies, including influent COD loading and pH, ORP, and batch duration operational setpoints were identified and used to further define reactor operating strategies that could maximize denitrification performance. Significant enrichment indicated *Thauera* sp. may represent a key functional microorganism in denitrification systems. This study implicated stoichiometric limitation of influent organic carbon, unique microbial community enrichment, and differential NO₃⁻ and NO₂⁻ reduction kinetics as determinant factors in glycerol-driven denitrification.

ADDITIONAL INFORMATION

E-supplementary data can be found in online version of the paper.

AUTHOR INFORMATION

ORCID

Matthew Baideme: 0000-0002-2556-0624

Kartik Chandran: 0000-0002-7526-3724

Author Contributions: The manuscript was written through contributions of all authors. All authors gave approval to the final version of the manuscript. All authors contributed equally.

Notes: The authors declare no competing financial interests.

ACKNOWLEDGMENTS

This study was supported by Project Director, Joint Services, project USMA1740. Views and opinions expressed or implied herein are solely those of the authors and should not be construed as policy or carrying the official sanction of the Department of Defense, United States Army, United States Military Academy, or other agencies or departments of the U.S. Government.

REFERENCES

- 1 C. S. Srinandan, M. Shah, B. Patel and A. S. Nerurkar, *Bioresour. Technol.*, 2011, **102**, 9481–9489.
- 2 P. Cyplik, R. Marecik, A. Piotrowska-Cyplik, A. Olejnik, A. Drożdżyńska and Ł. Chrzanowski, *Water, Air, Soil Pollut.*, 2012, **223**, 1791–1800.
- 3 J. Shen, R. He, W. Han, X. Sun, J. Li and L. Wang, *J. Hazard. Mater.*, 2009, **172**, 595–600.
- 4 S. Cao, R. Du, B. Li, S. Wang, N. Ren and Y. Peng, *Chem. Eng. J.*, 2017, **326**, 1186–1196.
- 5 S. Cao, S. Wang, Y. Peng, C. Wu, R. Du, L. Gong and B. Ma, *Bioresour. Technol.*, 2013, **149**, 570–574.

499 6 R. Du, Y. Peng, S. Cao, B. Li, S. Wang and M. Niu, *Appl. Microbiol. Biotechnol.*, 2016, **100**,
500 2011–2021.

501 7 S. Ge, Y. Peng, S. Wang, C. Lu, X. Cao and Y. Zhu, *Bioresour. Technol.*, 2012, **114**, 137–
502 143.

503 8 W. Li, X.-Y. Lin, J.-J. Chen, C.-Y. Cai, G. Abbas, Z.-Q. Hu, H.-P. Zhao and P. Zheng, *Appl.*
504 *Microbiol. Biotechnol.*, 2016, **100**, 10203–10213.

505 9 Z. Si, Y. Peng, A. Yang, S. Zhang, B. Li, B. Wang and S. Wang, *Environ. Sci.: Water Res.*
506 *Technol.*, 2018, **4**, 80–86.

507 10 L. Russ, D. R. Speth, M. S. M. Jetten, H. J. M. Op den Camp and B. Kartal, *Environ.*
508 *Microbiol.*, 2014, **16**, 3487–3498.

509 11 K. Hanaki, Z. Hong and T. Matsuo, *Water Sci. Technol.*, 1992, **26**, 1027–1036.

510 12 V. Baytshtok, H. Lu, H. Park, S. Kim, R. Yu and K. Chandran, *Biotechnol. Bioeng.*, 2009,
511 **102**, 1527–1536.

512 13 D. Richardson, H. Felgate, N. Watmough, A. Thomson and E. Baggs, *Trends in*
513 *Biotechnology*, 2009, **27**, 388–397.

514 14 J. van Rijn, Y. Tal and Y. Barak, *Appl. Environ. Microbiol.*, 1996, **62**, 2615–2620.

515 15 H. W. van Verseveld and A. H. Stouthamer, *Arch. Microbiol.*, 1978, **118**, 13–20.

516 16 J. Hinojosa, R. Riffat, S. Fink, S. Murthy, K. Selock, C. Bott, I. Takacs, P. Dold and R.
517 Wimmer, in *Proceedings of the 81st Annual Water Environment Federation Technical*
518 *Exposition and Conference*, Chicago, 2008, pp. 274–288.

519 17 T. Le, B. Peng, C. Su, A. Massoudieh, A. Torrents, A. Al-Omari, S. Murthy, B. Wett, K.
520 Chandran, C. deBarbadillo, C. Bott and H. De Clippeleir, *Water Environ. Res.*, 2019, **91**,
521 1455–1465.

- 522 18 Y. Mokhayeri, R. Riffat, S. Murthy, W. Bailey, I. Takacs and C. Bott, *Water Science &*
523 *Technology*, 2009, **60**, 2485.
- 524 19 G. P. da Silva, M. Mack and J. Contiero, *Biotechnol. Adv.*, 2009, **27**, 30–39.
- 525 20 H. Lu and K. Chandran, *Environ. Sci. Technol.*, 2010, **44**, 8943–8949.
- 526 21 D. Güven, A. Dapena, B. Kartal, M. C. Schmid, B. Maas, K. van de Pas-Schoonen, S. Sozen,
527 R. Mendez, H. J. M. Op den Camp, M. S. M. Jetten, M. Strous and I. Schmidt, *Appl.*
528 *Environ. Microbiol.*, 2005, **71**, 1066–1071.
- 529 22 H. Park, A. C. Brotto, M. C. M. van Loosdrecht and K. Chandran, *Water Res.*, 2017, **111**,
530 265–273.
- 531 23 American Public Health Association, *Standard Methods for the Examination of Water and*
532 *Wastewater*, American Public Health Association, American Water Works Association,
533 Water Environment Federation, Washington, DC, 23rd edn., 2017.
- 534 24 E. M. Contreras, N. C. Bertola, L. Giannuzzi and N. E. Zaritzky, *Water SA*, 2002, **28**, 463–
535 468.
- 536 25 P. D. Schloss, S. L. Westcott, T. Ryabin, J. R. Hall, M. Hartmann, E. B. Hollister, R. A.
537 Lesniewski, B. B. Oakley, D. H. Parks, C. J. Robinson, J. W. Sahl, B. Stres, G. G. Thallinger,
538 D. J. V. Horn and C. F. Weber, *Appl. Environ. Microbiol.*, 2009, **75**, 7537–7541.
- 539 26 S. Chen, T. Huang, Y. Zhou, Y. Han, M. Xu and J. Gu, *BMC Bioinf.*, 2017, **18**, 91–100.
- 540 27 B. J. Callahan, P. J. McMurdie, M. J. Rosen, A. W. Han, A. J. A. Johnson and S. P. Holmes,
541 *Nat. Methods*, 2016, **13**, 581–583.
- 542 28 J. G. Caporaso, J. Kuczynski, J. Stombaugh, K. Bittinger, F. D. Bushman, E. K. Costello, N.
543 Fierer, A. G. Pena, J. K. Goodrich and J. I. Gordon, *Nat. Methods*, 2010, **7**, 335–336.
- 544 29 R. Du, Y. Peng, S. Cao, S. Wang and C. Wu, *Bioresour. Technol.*, 2015, **179**, 497–504.

545 30 P. L. McCarty, *Biotechnol. Bioeng.*, 2007, **97**, 377–388.

546 31 J. C. Akunna, C. Bizeau and R. Moletta, *Water Res.*, 1993, **27**, 1303–1312.

547 32 H. Constantin and M. Fick, *Water Res.*, 1997, **31**, 583–589.

548 33 H. Sun, Q. Yang, Y. Peng, X. Shi, S. Wang and S. Zhang, *Chin. J. Chem. Eng.*, 2009, **17**,
549 1027–1031.

550 34 R. Du, S. Cao, M. Niu, B. Li, S. Wang and Y. Peng, *Int. Biodeterior. Biodegrad.*, 2017, **122**,
551 38–46.

552 35 D. Güven, *Clean: Soil, Air, Water*, 2009, **37**, 565–573.

553 36 M. C. M. van Loosdrecht, M. A. Pot and J. J. Heijnen, *Water Sci. Technol.*, 1997, **35**, 41–47.

554 37 G. D. Drysdale, H. C. Kasan and F. Bux, *Water Sci. Technol.*, 2001, **43**, 147–154.

555 38 B. Liu, Y. Mao, L. Bergaust, L. R. Bakken and Å. Frostegård, *Environ. Microbiol.*, 2013, **15**,
556 2816–2828.

557 39 M. R. Betlach and J. M. Tiedje, *Appl. Environ. Microbiol.*, 1981, **42**, 1074–1084.

558 40 J. Dries, *Water Sci. Technol.*, 2015, **73**, 740–745.

559 41 L. Åmand, G. Olsson and B. Carlsson, *Water Sci. Technol.*, 2013, **67**, 2374–2398.

560 42 L. Gong, M. Huo, Q. Yang, J. Li, B. Ma, R. Zhu, S. Wang and Y. Peng, *Bioresour. Technol.*,
561 2013, **133**, 263–269.

562 43 Y. Z. Peng, J. F. Gao, S. Y. Wang and M. H. Sui, *Water Sci. Technol.*, 2002, **46**, 131–137.

563 44 C. P. L. Grady, G. T. Daigger, N. G. Love and C. D. M. Filipe, *Biological Wastewater*
564 *Treatment*, CRC Press, Boca Raton, FL, 3rd edn., 2011.

565 45 H. Lu, K. Chandran and D. Stensel, *Water Res.*, 2014, **64**, 237–254.

566 46 M. P. Ginige, J. Keller and L. L. Blackall, *Appl. Environ. Microbiol.*, 2005, **71**, 8683–8691.

567 47 C. Etchebehere, I. Errazquin, E. Barrandeguy, P. Dabert and R. Moletta, *FEMS Microbiol.*
568 *Ecol.*, 2001, **35**, 259–265.

569 48 L. Bergaust, L. R. Bakken and Å. Frostegård, *Biochem. Soc. Trans.*, 2011, **39**, 207–212.

570 49 R. Du, S. Cao, B. Li, M. Niu, S. Wang and Y. Peng, *Water Res.*, 2017, **108**, 46–56.

571 50 T. R. Thomsen, Y. Kong and P. H. Nielsen, *FEMS Microbiol. Ecol.*, 2007, **60**, 370–382.

572 51 C. Glass and J. Silverstein, *Water Res.*, 1998, **32**, 831–839.

573

Figure 1. Steady-state denitrification performance and respective NAR and NRR assessed at each influent COD:NO₃⁻-N ratio. *Effluent gaseous-N contributions were calculated via mass balance.

578 **Table 1. Influence of external COD source and influent COD:NO₃⁻-N ratios on denitratation**
 579 *performance.*

External COD Source	Influent COD:NO ₃ ⁻ -N	NAR [%]	NRR [%]	Reactor Type	Source
Sodium Acetate	3.0	51 – 73	~73 - 93	USB ^a	34
	3.0	80	~100	SBR	6
	2.75	83	~100		34
	2.5	87	85		9
Sodium Acetate / Domestic Wastewater	3.1 ^b	90	~100		4
Fermentation Effluent	3.0	80	~100		5
Glycerol	2.5	65	54		This study
	2.8	69	73		
	3.0	62	96		
	4.0	57	97		
	5.0	10	99		

^a Upflow sludge blanket reactor (USB)

^b Reported influent ratio includes COD associated both with the domestic wastewater and external COD source

Table 2. Summary of process kinetic parameters for both full denitrification and denitratation studies with respect to external COD source and influent COD:NO₃⁻-N ratio.

COD Source	Inf. COD:NO ₃ ⁻ -N	Inf. NO ₃ ⁻ -N [mg N/L]	μ _{max} [d ⁻¹]	sDNaR ^h [mg N/g VSS/h]	sDNiR ⁱ [mg N/g VSS/h]	Source
Sodium Acetate	1.22	2,700	--	23.0 ^f	19.0 ^f	51
	5.0	150	--	82.3	32.0	6
	1.0	--	--	52.0	--	7
	6.0	--	--	280.0	--	
Sodium Acetate / Domestic WW	3.4 ^e	1,000	--	190.0	--	4
Glycerol	5.0	100	--	6.5 ^{a,d}		20
	26.0	22.5	3.4	1.7 ^{a,b}		16
	26.0	22.5	2.0	1.35 ^{a,c}		
	2.5	100	--	112.3	1.8	This Study
	3.0	100	--	135.3	14.9	
	5.0	100	--	147.1	40.0	
	20.0 ^g (Unlimited)	100	6.2	--	--	

^a Rates reported as mg NO_x-N/g VSS/hr based upon full denitrification studies.

^b Rate reported in study exhibiting no NO₂⁻ accumulation.

^c Rate reported in study exhibiting NO₂⁻ accumulation.

^d Suspended phase rates reported; biofilm rates not reported for comparison purposes to current study.

^e Reported influent ratio includes COD associated both with the domestic wastewater and external COD source.

^f Rates reported from original study for the pH utilized in current study.

^g Batch experiment used biomass acclimated to influent COD:NO₃⁻-N=3.0.

^h Specific rate of NO₃⁻ reduction (sDNaR)

ⁱ Specific rates of NO₂⁻ reduction (sDNiR)

Figure 2. Representative in situ NO_2^- -N profiles identified the optimal batch duration obtained during steady-state operation at each respective influent COD: NO_3^- -N ratio. Optimal batch durations corresponded to the points of maximum NO_2^- accumulation at each respective influent COD: NO_3^- -N ratio. Decreases in NO_2^- concentrations during the feed and react period were attributed to dilution.

Figure 3. NO_x , pH, and ORP profiles depicting the pH (a) and ORP (b) inflection points at the point of maximum NO_2^- accumulation prior to which denitrification was dominant and after which denitrification became dominant (influent $\text{COD}:\text{NO}_3^-\text{-N}=10.0:1$; microbial ecology acclimated to influent $\text{COD}:\text{NO}_3^-\text{-N}=3.0:1$). Influent COD was provided in excess and beyond that at which biomass was acclimated in order to drive the process beyond denitrification and demonstrate the ability of pH and ORP to serve as denitrification process controls even under non-ideal influent $\text{COD}:\text{NO}_3^-\text{-N}$ ratios.

Figure 4. Taxonomic analysis of the microbial consortium at the phylum (a) and genus (b) taxonomic levels under optimal operating conditions (influent COD:NO₃⁻-N=3.0:1, SRT=3 d). The grouping “Other” comprises OTUs with less than 1% total relative abundance (among all samples summed).